



TESTMARK Laboratories Ltd.

Committed to Quality and Service

Analytical Report

Client:	Mark Bocy	Work Order Number:	82192
Company:	SRDSB - Adamsdale Public School	Date Order Received:	06/15/09
Address:	69 Young St Sudbury, ON, P3E 3G5	Regulation:	O.Reg. 243/07
Phone:	(705) 674-3171	PO #:	
Fax:	(705) 761-2442	Project #:	
Email:	bocym@rainbowschools.ca	DWS#:	500039131

Analyses were performed on the following samples submitted with your order.

The results relate only to the items tested.

Sample Name	Lab #	Matrix	Type	Comments	Date Collected	Time Collected
APS - 01 - S (standing) (staff room)	232489	Water	Plumbing		06/14/09	12:40
APS - 01 - F (flushing) (staff room)	232490	Water	Plumbing		06/14/09	13:15
APS - 02 - S (standing) (breakfast club ro	232491	Water	Plumbing		06/14/09	12:55
APS - 02 - F (Flushing) (breakfast club ro	232492	Water	Plumbing		06/14/09	13:30

The following instrumentation and reference methods were used for your sample(s)

Method Name	Description	Reference
ICPMS Water	Determination of Metals in Water by ICP/MS Instrument group: Perkin Elmer ICPMS	Mod. SW846-6020

This report has been approved by:

Brad Halvorson, B. Sc.
Inorganic Section Head



TESTMARK Laboratories Ltd.

Committed to Quality and Service

SRDSB - Adamsdale Public School

Work Order: 82192

Sample Data:

Sample Name: APS - 01 - S (standing) (staff ro Date: 06/14/09 Matrix: Water Lab #: 232489

ICPMS Water				
Parameter	MDL	Result	Units	QAQCID
Lead	1	<1	ug/L	20090617.R13F

Sample Name: APS - 01 - F (flushing) (staff ro Date: 06/14/09 Matrix: Water Lab #: 232490

ICPMS Water				
Parameter	MDL	Result	Units	QAQCID
Lead	1	<1	ug/L	20090617.R13F

Sample Name: APS - 02 - S (standing) (breakfa Date: 06/14/09 Matrix: Water Lab #: 232491

ICPMS Water				
Parameter	MDL	Result	Units	QAQCID
Lead	1	<1	ug/L	20090617.R13F

Sample Name: APS - 02 - F (Flushing) (breakfa Date: 06/14/09 Matrix: Water Lab #: 232492

ICPMS Water				
Parameter	MDL	Result	Units	QAQCID
Lead	1	<1	ug/L	20090617.R13F

MDL Method detection limit or minimum reporting limit.

% Rec Surrogate compounds are added to the sample in some cases and the recovery is reported as a percent recovered.

QAQCID This is a unique reference to the quality control data set used to generate the reported value.

Data reported for organic analysis in soil samples are corrected for moisture content

Matrix If the matrix is a leachate, the sample was extracted according to regulation 558.

INT Interferences

TNTC Too numerous to count

ND Not detected