



# TESTMARK Laboratories Ltd.

Committed to Quality and Service

## Analytical Report

---

<b>Client:</b>	Mark Bocy	<b>Work Order Number:</b>	<b>81433</b>
<b>Company:</b>	SRDSB - Larchwood Public School	<b>Date Order Received:</b>	06/04/09
<b>Address:</b>	69 Young St. Sudbury, ON, P3E 3G5	<b>Regulation:</b>	O.Reg. 243/07
<b>Phone:</b>	(705) 674-3171	<b>PO #:</b>	
<b>Fax:</b>	(705) 671-2442	<b>Project #:</b>	
<b>Email:</b>	bocym@rainbowschools.ca	<b>DWS#:</b>	

---

Analyses were performed on the following samples submitted with your order.

The results relate only to the items tested.

Sample Name	Lab #	Matrix	Type	Comments	Date Collected	Time Collected
STANDING TEACHERS ROOM	230473	Water	Plumbing		06/03/09	6:04
FLUSHING TEACHERS ROOM	230474	Water	Plumbing		06/03/09	6:39

The following instrumentation and reference methods were used for your sample(s)

Method Name	Description	Reference
ICPMS Water	Determination of Metals in Water by ICP/MS Instrument group: Perkin Elmer ICPMS	Mod. SW846-6020

This report has been approved by:

Brad Halvorson, B. Sc.  
Inorganic Section Head



# TESTMARK Laboratories Ltd.

Committed to Quality and Service

SRDSB - Larchwood Public School

Work Order: 81433

## Sample Data:

Sample Name: **STANDING TEACHERS ROOM** Date: **06/03/09** Matrix: **Water** Lab #: **230473**

ICPMS Water				
Parameter	MDL	Result	Units	QAQCID
Lead	1	<1	ug/L	20090608.R13P

Sample Name: **FLUSHING TEACHERS ROOM** Date: **06/03/09** Matrix: **Water** Lab #: **230474**

ICPMS Water				
Parameter	MDL	Result	Units	QAQCID
Lead	1	<1	ug/L	20090608.R13P

**MDL** Method detection limit or minimum reporting limit.

**% Rec** Surrogate compounds are added to the sample in some cases and the recovery is reported as a percent recovered.

**QAQCID** This is a unique reference to the quality control data set used to generate the reported value.

**Data reported for organic analysis in soil samples are corrected for moisture content**

**Matrix** If the matrix is a leachate, the sample was extracted according to regulation 558.

**INT** Interferences

**TNTC** Too numerous to count

**ND** Not detected