



TESTMARK Laboratories Ltd.

Committed to Quality and Service

Analytical Report

Client:	Mark Bocy	Work Order Number:	82183
Company:	SRDSB - Lasalle Secondary School	Date Order Received:	06/15/09
Address:	69 Young St Sudbury, ON, P3E 3G5	Regulation:	O.Reg. 243/07
Phone:	(705) 674-3171	PO #:	
Fax:	(705) 761-2442	Project #:	
Email:	bocym@rainbowschools.ca	DWS#:	500045995

Analyses were performed on the following samples submitted with your order.

The results relate only to the items tested.

Sample Name	Lab #	Matrix	Type	Comments	Date Collected	Time Collected
LSS - 01 - S (room 100) (Standing)	232389	Water	Plumbing		06/14/09	10:00
LSS - 02 - S (staff room) (STANDING)	232390	Water	Plumbing		06/14/09	10:07
LSS - 03 - S (food services) (STANDING)	232391	Water	Plumbing		06/14/09	10:17
LSS - 01 - F (Room 100) Flushing	232392	Water	Plumbing		06/14/09	10:35
LSS - 02 - F (staff room) Flushing	232393	Water	Plumbing		06/14/09	10:42
LSS - 03 - F (food services)	232394	Water	Plumbing		06/14/09	10:52

The following instrumentation and reference methods were used for your sample(s)

Method Name	Description	Reference
ICPMS Water	Determination of Metals in Water by ICP/MS Instrument group: Perkin Elmer ICPMS	Mod. SW846-6020

This report has been approved by:

Brad Halvorson, B. Sc.
Inorganic Section Head



TESTMARK Laboratories Ltd.

Committed to Quality and Service

SRDSB - Lasalle Secondary School

Work Order: 82183

Sample Data:

Sample Name: LSS - 01 - S (room 100) (Standin Date: 06/14/09 Matrix: Water Lab #: 232389

ICPMS Water				
Parameter	MDL	Result	Units	QAQCID
Lead	1	<1	ug/L	20090617.R13F

Sample Name: LSS - 02 - S (staff room) (STAN Date: 06/14/09 Matrix: Water Lab #: 232390

ICPMS Water				
Parameter	MDL	Result	Units	QAQCID
Lead	1	1.3	ug/L	20090617.R13F

Sample Name: LSS - 03 - S (food services) (ST Date: 06/14/09 Matrix: Water Lab #: 232391

ICPMS Water				
Parameter	MDL	Result	Units	QAQCID
Lead	1	<1	ug/L	20090617.R13F

Sample Name: LSS - 01 - F (Room 100) Flushin Date: 06/14/09 Matrix: Water Lab #: 232392

ICPMS Water				
Parameter	MDL	Result	Units	QAQCID
Lead	1	<1	ug/L	20090617.R13F

Sample Name: LSS - 02 - F (staff room) Flushin Date: 06/14/09 Matrix: Water Lab #: 232393

ICPMS Water				
Parameter	MDL	Result	Units	QAQCID
Lead	1	<1	ug/L	20090617.R13F

Sample Name: LSS - 03 - F (food services) Date: 06/14/09 Matrix: Water Lab #: 232394

ICPMS Water				
Parameter	MDL	Result	Units	QAQCID
Lead	1	<1	ug/L	20090617.R13F



TESTMARK Laboratories Ltd.

Committed to Quality and Service

SRDSB - Lasalle Secondary School

Work Order: 82183

MDL Method detection limit or minimum reporting limit.

% Rec Surrogate compounds are added to the sample in some cases and the recovery is reported as a percent recovered.

QAQCID This is a unique reference to the quality control data set used to generate the reported value.

Data reported for organic analysis in soil samples are corrected for moisture content

Matrix If the matrix is a leachate, the sample was extracted according to regulation 558.

INT Interferences

TNTC Too numerous to count

ND Not detected