



TESTMARK Laboratories Ltd.

Committed to Quality and Service

Analytical Report

Client:	Mark Bocy	Work Order Number:	81431
Company:	SRDSB - Levack Public School	Date Order Received:	06/04/09
Address:	69 Young St. Sudbury, ON, P3E 3G5	Regulation:	O.Reg. 243/07
Phone:	(705) 674-3171	PO #:	
Fax:	(705) 671-2442	Project #:	
Email:	bocym@rainbowschools.ca	DWS#:	500045787

Analyses were performed on the following samples submitted with your order.

The results relate only to the items tested.

Sample Name	Lab #	Matrix	Type	Comments	Date Collected	Time Collected
STANDING DAYCARE ROOM 122 MIDD	230471	Water	Plumbing		06/03/09	5:14
FLUSHING DAYCARE ROOM 122 MIDD	230472	Water	Plumbing		06/03/09	5:49

The following instrumentation and reference methods were used for your sample(s)

Method Name	Description	Reference
ICPMS Water	Determination of Metals in Water by ICP/MS Instrument group: Perkin Elmer ICPMS	Mod. SW846-6020

This report has been approved by:

Brad Halvorson, B. Sc.
Inorganic Section Head



TESTMARK Laboratories Ltd.

Committed to Quality and Service

SRDSB - Leveck Public School

Work Order: 81431

Sample Data:

Sample Name: STANDING DAYCARE ROOM 12 Date: 06/03/09

Matrix: Water

Lab #: 230471

ICPMS Water				
Parameter	MDL	Result	Units	QAQCID
Lead	1	<1	ug/L	20090608.R13P

Sample Name: FLUSHING DAYCARE ROOM 12 Date: 06/03/09

Matrix: Water

Lab #: 230472

ICPMS Water				
Parameter	MDL	Result	Units	QAQCID
Lead	1	<1	ug/L	20090608.R13P

MDL Method detection limit or minimum reporting limit.

% Rec Surrogate compounds are added to the sample in some cases and the recovery is reported as a percent recovered.

QAQCID This is a unique reference to the quality control data set used to generate the reported value.

Data reported for organic analysis in soil samples are corrected for moisture content

Matrix If the matrix is a leachate, the sample was extracted according to regulation 558.

INT Interferences

TNTC Too numerous to count

ND Not detected