



# TESTMARK Laboratories Ltd.

Committed to Quality and Service

## Analytical Report

---

<b>Client:</b>	Mark Bocy	<b>Work Order Number:</b>	<b>81604</b>
<b>Company:</b>	SRDSB - Long Lake Public School (Longlake Road)	<b>Date Order Received:</b>	06/08/09
<b>Address:</b>	69 Young St Sudbury, ON, P3E 3G5	<b>Regulation:</b>	O.Reg. 243/07
<b>Phone:</b>	(705) 674-3171	<b>PO #:</b>	
<b>Fax:</b>	(705) 671-2442	<b>Project #:</b>	
		<b>DWS#:</b>	500040353

---

Analyses were performed on the following samples submitted with your order.

The results relate only to the items tested.

Sample Name	Lab #	Matrix	Type	Comments	Date Collected	Time Collected
STANDING STAFF ROOM	230875	Water	Plumbing		06/07/09	10:50
FLUSHING STAFF ROOM	230876	Water	Plumbing		06/07/09	11:25

The following instrumentation and reference methods were used for your sample(s)

Method Name	Description	Reference
ICPMS Water	Determination of Metals in Water by ICP/MS Instrument group: Perkin Elmer ICPMS	Mod. SW846-6020

This report has been approved by:

Brad Halvorson, B. Sc.  
Inorganic Section Head



# TESTMARK Laboratories Ltd.

Committed to Quality and Service

SRDSB - Long Lake Public School (Longlake Road)

Work Order: 81604

## Sample Data:

Sample Name: **STANDING STAFF ROOM**      Date: **06/07/09**      Matrix: **Water**      Lab #: **230875**

ICPMS Water				
Parameter	MDL	Result	Units	QAQCID
Lead	1	4.4	ug/L	20090609.R13B

Sample Name: **FLUSHING STAFF ROOM**      Date: **06/07/09**      Matrix: **Water**      Lab #: **230876**

ICPMS Water				
Parameter	MDL	Result	Units	QAQCID
Lead	1	<1	ug/L	20090609.R13B

*MDL*      Method detection limit or minimum reporting limit.

*% Rec*      Surrogate compounds are added to the sample in some cases and the recovery is reported as a percent recovered.

*QAQCID*      This is a unique reference to the quality control data set used to generate the reported value.

*Data reported for organic analysis in soil samples are corrected for moisture content*

*Matrix*      If the matrix is a leachate, the sample was extracted according to regulation 558.

*INT*      Interferences

*TNTC*      Too numerous to count

*ND*      Not detected