



# TESTMARK Laboratories Ltd.

Committed to Quality and Service

## Analytical Report

---

<b>Client:</b>	Mark Bocy	<b>Work Order Number:</b>	<b>81635</b>
<b>Company:</b>	SRDSB - Pinecrest Public School	<b>Date Order Received:</b>	06/08/09
<b>Address:</b>	69 Young St. Sudbury, ON, P3E 3G5	<b>Regulation:</b>	O.Reg. 243/07
<b>Phone:</b>	(705) 674-3171	<b>PO #:</b>	
<b>Fax:</b>	(705) 761-2442	<b>Project #:</b>	
<b>Email:</b>	bocym@rainbowschools.ca	<b>DWS#:</b>	500040327

---

Analyses were performed on the following samples submitted with your order.

The results relate only to the items tested.

Sample Name	Lab #	Matrix	Type	Comments	Date Collected	Time Collected
STANDING STAFF ROOM	230946	Water	Plumbing		06/07/09	9:51
FLUSHED STAFF ROOM	230947	Water	Plumbing		06/07/09	10:26

The following instrumentation and reference methods were used for your sample(s)

Method Name	Description	Reference
ICPMS Water	Determination of Metals in Water by ICP/MS Instrument group: Perkin Elmer ICPMS	Mod. SW846-6020

This report has been approved by:

Brad Halvorson, B. Sc.  
Inorganic Section Head



# TESTMARK Laboratories Ltd.

Committed to Quality and Service

SRDSB - Pinecrest Public School

Work Order: 81635

## Sample Data:

Sample Name: STANDING STAFF ROOM      Date: 06/07/09      Matrix: Water      Lab #: 230946

ICPMS Water				
Parameter	MDL	Result	Units	QAQCID
Lead	1	<1	ug/L	20090610.R13E

Sample Name: FLUSHED STAFF ROOM      Date: 06/07/09      Matrix: Water      Lab #: 230947

ICPMS Water				
Parameter	MDL	Result	Units	QAQCID
Lead	1	<1	ug/L	20090610.R13E

- MDL      Method detection limit or minimum reporting limit.
- % Rec    Surrogate compounds are added to the sample in some cases and the recovery is reported as a percent recovered.
- QAQCID    This is a unique reference to the quality control data set used to generate the reported value.
- Data reported for organic analysis in soil samples are corrected for moisture content
- Matrix    If the matrix is a leachate, the sample was extracted according to regulation 558.
- INT      Interferences
- TNTC    Too numerous to count
- ND      Not detected

## Quality Control Data:

### ICPMS Water

Blank						
Parameter	MDL	Units	UCL	Result	LCL	QAQCID
Lead	1	ug/L	1	<1	<1	20090610.R13E

Positive Control (1011)						
Parameter	MDL	Units	UCL	Result	LCL	QAQCID
Lead	1	ug/L	120	91.8	80	20090610.R13E

UCL Upper Control Limit  
LCL Lower Control Limit