



TESTMARK Laboratories Ltd.

Committed to Quality and Service

Analytical Report

Client:	Mark Bocy	Work Order Number:	246435
Company:	RDSB - Markstay Public School	Date Order Received:	6/30/2015
Address:	69 Young St Sudbury, ON, P3E 3G5	Regulation:	O.Reg. 243/07
Phone:	(705) 690-0323	PO #:	
Fax:	(705) 671-2442	Project #:	
Email:	bocym@rainbowschools.ca; lavallm@rainbowschools.ca	DWS#:	500045618
Notes:	Standing: GREATER THEN 10 HRS		

Analyses were performed on the following samples submitted with your order.

The results relate only to the items tested.

Sample Name	Lab #	Matrix	Type	Comments	Date Collected	Time Collected
MAR-STAN	650213	Water	Plumbing		6/28/2015	9:32
MAR-FLU	650214	Water	Plumbing		6/28/2015	10:07

The following instrumentation and reference methods were used for your sample(s)

Method Name	Description	Reference
ICPMS Water	Determination of Metals in Water by ICP/MS Instrument group: Perkin Elmer ICPMS	Based on SW846-6020A

This report has been approved by:

Khaled Omari, Ph.D.
Laboratory Director



TESTMARK Laboratories Ltd.

Committed to Quality and Service

RDSB - Markstay Public School

Work Order: 246435

Sample Data:

Sample Name: MAR-STAN

Date: 6/28/2015

Matrix: Water

Lab #: 650213

ICPMS Water				
Parameter	MDL	Result	Units	QAQCID
Lead	0.1	1.45	ug/L	20150708.R13-5o5

Sample Name: MAR-FLU

Date: 6/28/2015

Matrix: Water

Lab #: 650214

ICPMS Water				
Parameter	MDL	Result	Units	QAQCID
Lead	0.1	0.38	ug/L	20150708.R13-5o5

MDL Method detection limit or minimum reporting limit.

% Rec Surrogate compounds are added to the sample in some cases and the recovery is reported as a percent recovered.

QAQCID This is a unique reference to the quality control data set used to generate the reported value.

Data reported for organic analysis in soil samples are corrected for moisture content

Matrix If the matrix is a leachate, the sample was extracted according to regulation 558.

INT Interferences

TNTC Too numerous to count

ND Not detected

NDOGN No Data, Overgrown with Non-Target

NDOGT No Data, Overgrown with Target

NDOGHPC No Data, Overgrown HPC



TESTMARK Laboratories Ltd.

Committed to Quality and Service

RDSB - Markstay Public School

Work Order: 246435

Quality Control Data:

ICPMS Water

% RPD						
Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	N/A	%	0	N/A	20	20150708.R13-5o5

EP-L-3

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	N/A	% Rec	80	91.3	120	20150708.R13-5o5

Lab Control Sample

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	N/A	%	80	89	120	20150708.R13-5o5

Matrix Spike

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	N/A	% Rec	70	89.7	130	20150708.R13-5o5

Method Blank

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	1	ug/L	<1	<1	1	20150708.R13-5o5

UCL Upper Control Limit

LCL Lower Control Limit

TESTMARK Laboratories Ltd.
Committed to Quality and Service

7 Margaret St.

677 MacDonald Ave., Unit 7

Garson, ON CANADA P3L 1E1

Sault Ste. Marie, ON CANADA P6B 1J4

Phone: (705) 693-1121 Fax: (705) 693-1124

Phone: (705) 254-7117 Fax: (705) 254-3820

Email: customer.service@testmark.ca

Email: ssm@testmark.ca

Client: RDSB-Marketay PS
Address: 69 Young Street
Sudbury, ON P3E 3G5
Contact: Mark Bocy/Mike Lavallee
M.B.(705) 522-7750 ext 6539
M.L.(705) 566-2280 ext 6339
Phone:

Testmark Quote #: _____
Client P.O. #: _____
Client Project #: _____
Email Address: bocym@rainbowschools.ca
lavallm@rainbowschools.ca
Fax: (705)-566-2732

REPORTING/INVOICING FORMAT				TURN AROUND TIME (TAT)*		ANALYSIS REQUESTED								LABORATORY USE ONLY		
email				STANDARD		RESIDUAL CHLORINE (IF APPLICABLE)								CONTAINERS RECEIVED	WORK ORDER NUMBER:	
QC DATA REPORTED yes				Thurs 9											246435	
SAMPLE DISPOSAL yes				SPECIFIC DATE: <u>Thurs 9</u>												
SAMPLING				SAMPLE DESCRIPTION												
DATE	TIME	TYPE	MATRIX	(This Will Appear On The Report)		LEAD										
28/06/2015	9:32	p	w	MAR-STAN		X						1	14	650213	16P	
28/06/2016	10:07	p	w	MAR-FLU		X						1	14	650214	16P	

CONFIRMATION REPORT SENT

LEGEND TYPE: **G**=Grab, **C**=Composite **OR R**=Raw, **E**=Entry/Treated, **D**=Distribution,
P=Plumbing (O.REG. 170/O.REG. 318/319/O.REG. 243)
MATRIX: **B**=Blota, **GW**=Ground Water, **O**=Oil, **P**=Paint, **S**=Soil, **SD**=Sediment,
SL=Sludge, **SW**=Surface Water, **W**=Water

Waterworks # 500045618
Are these water samples for human consumption? reg 243
Are the results reportable as per O. Reg 170/318/319?
O.Reg 170/318/319 Only: Phone: (705) 522-9200
Public Health Unit: SDHU Fax: (705) 677-9607
Adverse and Exceedance Notification Information:
Name: Mark Bocy Cell: (705) 690-0323
Phone: (705) 674-3171 Fax: (705) 671-2442

COMMENTS: STANDING: GREATER THEN 10 HRS.
SAMPLE TAKEN FROM

Relinquished to Testmark By (Signature) M. Bocy 30/06/2015 Time 14:53

Sampled By (Print and Sign) M.LAVALLEE Date 28/06/2015 Time 09:32

Shipped By Hand Shipping Reference

Received By (Print and Sign) M.LAVALLEE Date Time

Received at Testmark By Jessica Date 30/06/15 Time 14:53