



## CERTIFICATE OF ANALYSIS

Client: Mark Bocy  
Company: RDSB - Assiginack Public School  
Address: 69 Young St.  
Sudbury, ON, P3E 3G5  
Phone/Fax: (705) 690-0323 / (705) 671-2442  
Email: bocym@rainbowschools.ca;  
lavallm@rainbowschools.ca

Work Order Number: 309130  
PO #:   
Regulation: O.Reg. 243/07  
Project #:   
DWS #: 500001132  
Sampled By: Kent C

Date Order Received: 6/20/2017  
Arrival Temperature: 16 °C

Analysis Started: 6/23/2017  
Analysis Completed: 6/26/2017

### WORK ORDER SUMMARY

ANALYSES WERE PERFORMED ON THE FOLLOWING SAMPLES. THE RESULTS RELATE ONLY TO THE ITEMS TESTED.

Sample Description	Lab ID	Matrix	Type	Comments	Date Collected	Time Collected
127 (Standing)	889329	Water	Plumbing	SAMPLE CONTAINED RESULT EXCEEDENCES.	6/20/2017	7:00 AM
127 (Flushed)	889330	Water	Plumbing		6/20/2017	7:35 AM
105 (Standing)	889331	Water	Plumbing		6/20/2017	7:02 AM
105 (Flushed)	889332	Water	Plumbing		6/20/2017	7:37 AM
124 (Standing)	889333	Water	Plumbing		6/20/2017	7:04 AM
124 (Flushed)	889334	Water	Plumbing		6/20/2017	7:39 AM
B1 (Standing)	889335	Water	Plumbing		6/20/2017	7:06 AM
B1 (Flushed)	889336	Water	Plumbing		6/20/2017	7:41 AM

### METHODS AND INSTRUMENTATION

THE FOLLOWING METHODS WERE USED FOR YOUR SAMPLE(S):

Method	Lab	Description	Reference
ICPMS Reg. Water	Garson	Determination of Metals in Water by ICP/MS	Based on SW846-6020A

### REPORT COMMENTS

Estimated Standing Time 10 HRS  
Lead exceedance reported on samples 889329 and 889330. 06/26/17 RB



**TESTMARK Laboratories Ltd.**

*Committed to Quality and Service*

## CERTIFICATE OF ANALYSIS

RDSB - Assiginack Public School

Work Order Number: 309130

This report has been approved by:

Khaled Omari, Ph.D.  
Laboratory Director



## CERTIFICATE OF ANALYSIS

RDSB - Assiginack Public School

Work Order Number: 309130

### WORK ORDER RESULTS

Sample Description	127 (Standing)		127 (Flushed)		105 (Standing)		105 (Flushed)		Units	Criteria: O.Reg. 243/07
Lab ID	889329		889330		889331		889332			
Metals	Result	MDL	Result	MDL	Result	MDL	Result	MDL		
Lead	15.5	0.1	10	0.1	2.5 [2.49]	0.1	0.56	0.1	ug/L	10

  

Sample Description	124 (Standing)		124 (Flushed)		B1 (Standing)		B1 (Flushed)		Units	Criteria: O.Reg. 243/07
Lab ID	889333		889334		889335		889336			
Metals	Result	MDL	Result	MDL	Result	MDL	Result	MDL		
Lead	6.16	0.1	1.75	0.1	1.98	0.1	0.86	0.1	ug/L	10

### LEGEND

Dates: Dates are formatted as mm/dd/year throughout this report.

MDL: Method detection limit or minimum reporting limit.

[ ]: Results for laboratory replicates are shown in square brackets immediately below the associated sample result for ease of comparison.

Quality Control: All associated Quality Control data is available on request.