



CERTIFICATE OF ANALYSIS

Client: Mike Lavallee
Company: RDSB - C.R. Judd Public School
Address: 69 Young St.
Sudbury, ON, P3E 3G5
Phone/Fax: (705) 929-4787 / (705) 761-2442
Email: lavallm@rainbowschools.ca

Work Order Number: 319672
PO #: 706LW1736503
Regulation: O.Reg. 243/07
Project #:
DWS #: 500040301
Sampled By: Mike Lavallee

Date Order Received: 10/23/2017
Arrival Temperature: 8 °C

Analysis Started: 10/30/2017
Analysis Completed: 10/31/2017

WORK ORDER SUMMARY

ANALYSES WERE PERFORMED ON THE FOLLOWING SAMPLES. THE RESULTS RELATE ONLY TO THE ITEMS TESTED.

Sample Description	Lab ID	Matrix	Type	Comments	Date Collected	Time Collected
125-F-004 (S)	1018652	Treated Water	Plumbing		10/21/2017	9:30 AM
125-F-004 (F)	1018653	Treated Water	Plumbing		10/21/2017	10:05 AM
125-T-003 (S)	1018654	Treated Water	Plumbing		10/21/2017	9:31 AM
125-T-003 (F)	1018655	Treated Water	Plumbing		10/21/2017	10:06 AM
125-T-004 (S)	1018656	Treated Water	Plumbing		10/21/2017	9:32 AM
125-T-004 (F)	1018657	Treated Water	Plumbing		10/21/2017	10:07 AM
125-T-002 (S)	1018658	Treated Water	Plumbing		10/21/2017	9:35 AM
125-T-002 (F)	1018659	Treated Water	Plumbing		10/21/2017	10:10 AM

METHODS AND INSTRUMENTATION

THE FOLLOWING METHODS WERE USED FOR YOUR SAMPLE(S):

Method	Lab	Description	Reference
ICPMS Reg. Water (R13.1)	Garson	Determination of Metals in Water by ICP/MS	Based on SW846-6020A



TESTMARK Laboratories Ltd.

Committed to Quality and Service

CERTIFICATE OF ANALYSIS

RDSB - C.R. Judd Public School

Work Order Number: 319672

This report has been approved by:

Khaled Omari, Ph.D.
Laboratory Director



CERTIFICATE OF ANALYSIS

RDSB - C.R. Judd Public School

Work Order Number: 319672

WORK ORDER RESULTS

Sample Description	125 - F - 004 (S)		125 - F - 004 (F)		125 - T - 003 (S)		125 - T - 003 (F)			
Lab ID	1018652		1018653		1018654		1018655			
Metals	Result	MDL	Result	MDL	Result	MDL	Result	MDL	Units	Criteria: O.Reg. 243/07
Lead	0.25	0.1	<0.1	0.1	0.8	0.1	0.17	0.1	ug/L	10

Sample Description	125 - T - 004 (S)		125 - T - 004 (F)		125 - T - 002 (S)		125 - T - 002 (F)			
Lab ID	1018656		1018657		1018658		1018659			
Metals	Result	MDL	Result	MDL	Result	MDL	Result	MDL	Units	Criteria: O.Reg. 243/07
Lead	0.18	0.1	<0.1	0.1	0.35	0.1	0.13	0.1	ug/L	10

LEGEND

Dates: Dates are formatted as mm/dd/year throughout this report.

MDL: Method detection limit or minimum reporting limit.

Quality Control: All associated Quality Control data is available on request.