



TESTMARK Laboratories Ltd.

Committed to Quality and Service

CERTIFICATE OF ANALYSIS

Client: Mike Lavallee
Company: RDSB - Carl A. Nesbitt Public School
Address: 69 Young St.
Sudbury, ON, P3E 3G5
Phone/Fax: (705) 929-4787 / (705) 761-2442
Email: lavallm@rainbowschools.ca

Work Order Number: 319785
PO #: 706LW1736503
Regulation: O.Reg. 243/07
Project #:
DWS #: 500046034
Sampled By: K Dost

Date Order Received: 10/24/2017
Arrival Temperature: 19 °C

Analysis Started: 10/31/2017
Analysis Completed: 11/1/2017

WORK ORDER SUMMARY

ANALYSES WERE PERFORMED ON THE FOLLOWING SAMPLES. THE RESULTS RELATE ONLY TO THE ITEMS TESTED.

Sample Description	Lab ID	Matrix	Type	Comments	Date Collected	Time Collected
142-T-004(S)	1019154	Water	Plumbing		10/24/2017	6:30 AM
142-T-004(F)	1019155	Water	Plumbing		10/24/2017	7:05 AM

METHODS AND INSTRUMENTATION

THE FOLLOWING METHODS WERE USED FOR YOUR SAMPLE(S):

Method	Lab	Description	Reference
ICPMS Reg. Water (R13.1)	Garson	Determination of Metals in Water by ICP/MS	Based on SW846-6020A

This report has been approved by:

Khaled Omari, Ph.D.
Laboratory Director



CERTIFICATE OF ANALYSIS

RDSB - Carl A. Nesbitt Public School

Work Order Number: 319785

WORK ORDER RESULTS

Sample Description	142 - T - 004(S)		142 - T - 004(F)			
Lab ID	1019154		1019155			
Metals	Result	MDL	Result	MDL	Units	Criteria: O.Reg. 243/07
Lead	3.05 [3.02]	0.1	0.31	0.1	ug/L	10

LEGEND

Dates: Dates are formatted as mm/dd/year throughout this report.

MDL: Method detection limit or minimum reporting limit.

[]: Results for laboratory replicates are shown in square brackets immediately below the associated sample result for ease of comparison.

Quality Control: All associated Quality Control data is available on request.