



TESTMARK Laboratories Ltd.
Committed to Quality and Service

CERTIFICATE OF ANALYSIS

Client: Mike Lavallee
Company: RDSB - Carl A. Nesbitt Public School
Address: 69 Young St.
Sudbury, ON, P3E 3G5
Phone/Fax: (705) 929-4787 / (705) 761-2442
Email: lavallm@rainbowschools.ca

Work Order Number: 314084
PO #: 706LW1736503
Regulation: O.Reg. 243/07
Project #:
DWS #: 500046034
Sampled By: K Dost

Date Order Received: 8/18/2017
Arrival Temperature: 20 °C

Analysis Started: 8/22/2017
Analysis Completed: 8/23/2017

WORK ORDER SUMMARY

ANALYSES WERE PERFORMED ON THE FOLLOWING SAMPLES. THE RESULTS RELATE ONLY TO THE ITEMS TESTED.

Sample Description	Lab ID	Matrix	Type	Comments	Date Collected	Time Collected
142-S-002(S)	906870	Water	Plumbing	SAMPLE CONTAINED RESULT EXCEEDENCES.	8/18/2017	7:45 AM
142-S-002(F)	906871	Water	Plumbing		8/18/2017	8:20 AM

METHODS AND INSTRUMENTATION

THE FOLLOWING METHODS WERE USED FOR YOUR SAMPLE(S):

Method	Lab	Description	Reference
ICPMS Reg. Water (R13.1)	Garson	Determination of Metals in Water by ICP/MS	Based on SW846-6020A

REPORT COMMENTS

Lead exceedance reported for sample 906870. 08/23/17 JC
Standing in excess of 6 HRS
SAMPLE TAKEN FROM BREAKFAST CLUB FIRST RE-TEST

This report has been approved by:

Khaled Omari, Ph.D.
Laboratory Director



CERTIFICATE OF ANALYSIS

RDSB - Carl A. Nesbitt Public School

Work Order Number: 314084

WORK ORDER RESULTS

Sample Description	142 - S - 002(S)		142 - S - 002(F)			
Lab ID	906870		906871			
Metals	Result	MDL	Result	MDL	Units	Criteria: O.Reg. 243/07
Lead	17.3	0.1	2.34	0.1	ug/L	10

LEGEND

Dates: Dates are formatted as mm/dd/year throughout this report.

MDL: Method detection limit or minimum reporting limit.

Quality Control: All associated Quality Control data is available on request.

LCL: Lower Control Limit.

UCL: Upper Control Limit.

QAQCID: This is a unique reference to the quality control data set used to generate the reported value. Contact our lab for this information, as it is traceable through our LIMS.



CERTIFICATE OF ANALYSIS

RDSB - Carl A. Nesbitt Public School

Work Order Number: 314084

QUALITY CONTROL DATA

THIS SECTION REPORTS QC RESULTS ASSOCIATED WITH THE TEST BATCH; THESE ARE NOT YOUR SAMPLE RESULTS.
QAQC details include only values where sufficient sample data allowed measurement.

Metals							
Method Blank							
Parameter	MDL	Units	LCL	Result	UCL	QAQCID	
Lead	1	ug/L	0	<1	1	20170822.R13-6o0	
Positive Control							
Parameter	MDL	Units	LCL	Result	UCL	QAQCID	
Lead	N/A	%	80	90.5	120	20170822.R13-6o0	
Reference Sample							
Parameter	MDL	Units	LCL	Result	UCL	QAQCID	
Lead	N/A	% Rec	80	95.7	120	20170822.R13-6o0	
Sample Spike							
Parameter	MDL	Units	LCL	Result	UCL	QAQCID	
Lead	N/A	% Rec	70	88.8	130	20170822.R13-6o0	

THIS INDEX SHOWS HOW YOUR SAMPLES ARE ASSOCIATED TO THE CONTROLS INCLUDED IN THE IDENTIFIED BATCHES.

Sample Description	Lab ID	Method	QAQCID	Prep QAQCID
142 - S - 002(F)	906871	ICPMS Reg. Water (R13.1)	20170822.R13-6o0	20170822.R520
142 - S - 002(S)	906870	ICPMS Reg. Water (R13.1)	20170822.R13-6o0	20170822.R520