



CERTIFICATE OF ANALYSIS

Client: Mike Lavallee
Company: RDSB - Churchill Public School
Address: 69 Young St
Sudbury, ON, P3E 3G5
Phone/Fax: (705) 929-4787 / (705) 761-2442
Email: lavallm@rainbowschools.ca

Work Order Number: 314076
PO #: 706LW1736503
Regulation: O.Reg. 243/07
Project #:
DWS #: 500046047
Sampled By: Dave Huntington

Date Order Received: 8/18/2017
Arrival Temperature: 20 °C

Analysis Started: 8/22/2017
Analysis Completed: 8/23/2017

WORK ORDER SUMMARY

ANALYSES WERE PERFORMED ON THE FOLLOWING SAMPLES. THE RESULTS RELATE ONLY TO THE ITEMS TESTED.

Sample Description	Lab ID	Matrix	Type	Comments	Date Collected	Time Collected
109-T-002(S)	906858	Water	Plumbing		8/18/2017	6:30 AM
109-T-002(F)	906859	Water	Plumbing		8/18/2017	7:05 AM
109-T-001(S)	906860	Water	Plumbing	SAMPLE CONTAINED RESULT EXCEEDENCES.	8/18/2017	6:32 AM
109-T-001(F)	906861	Water	Plumbing		8/18/2017	7:07 AM

METHODS AND INSTRUMENTATION

THE FOLLOWING METHODS WERE USED FOR YOUR SAMPLE(S):

Method	Lab	Description	Reference
ICPMS Reg. Water (R13.1)	Garson	Determination of Metals in Water by ICP/MS	Based on SW846-6020A

REPORT COMMENTS

Lead exceedance reported for sample 906860. 08/23/17 JC
Standing in excess of 6 HRS
SAMPLE TAKEN FROM BREAKFAST CLUB FIRST RE-TEST



TESTMARK Laboratories Ltd.

Committed to Quality and Service

CERTIFICATE OF ANALYSIS

RDSB - Churchill Public School

Work Order Number: 314076

This report has been approved by:

Khaled Omari, Ph.D.
Laboratory Director



CERTIFICATE OF ANALYSIS

RDSB - Churchill Public School

Work Order Number: 314076

WORK ORDER RESULTS

Sample Description	109 - T - 002(S)		109 - T - 002(F)		109 - T - 001(S)		109 - T - 001(F)			
Lab ID	906858		906859		906860		906861			
Metals	Result	MDL	Result	MDL	Result	MDL	Result	MDL	Units	Criteria: O.Reg. 243/07
Lead	<0.1	0.1	0.44	0.1	58.8	0.1	0.33	0.1	ug/L	10

LEGEND

Dates: Dates are formatted as mm/dd/year throughout this report.

MDL: Method detection limit or minimum reporting limit.

Quality Control: All associated Quality Control data is available on request.

LCL: Lower Control Limit.

UCL: Upper Control Limit.

QAQCID: This is a unique reference to the quality control data set used to generate the reported value. Contact our lab for this information, as it is traceable through our LIMS.



CERTIFICATE OF ANALYSIS

RDSB - Churchill Public School

Work Order Number: 314076

QUALITY CONTROL DATA

THIS SECTION REPORTS QC RESULTS ASSOCIATED WITH THE TEST BATCH; THESE ARE NOT YOUR SAMPLE RESULTS.
QAQC details include only values where sufficient sample data allowed measurement.

Metals						
Method Blank						
Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	1	ug/L	0	<1	1	20170822.R13-6o0
Positive Control						
Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	N/A	%	80	90.5	120	20170822.R13-6o0
Reference Sample						
Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	N/A	% Rec	80	95.7	120	20170822.R13-6o0
Sample Spike						
Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	N/A	% Rec	70	88.8	130	20170822.R13-6o0

THIS INDEX SHOWS HOW YOUR SAMPLES ARE ASSOCIATED TO THE CONTROLS INCLUDED IN THE IDENTIFIED BATCHES.

Sample Description	Lab ID	Method	QAQCID	Prep QAQCID
109 - T - 001(F)	906861	ICPMS Reg. Water (R13.1)	20170822.R13-6o0	20170822.R520
109 - T - 001(S)	906860	ICPMS Reg. Water (R13.1)	20170822.R13-6o0	20170822.R520
109 - T - 002(F)	906859	ICPMS Reg. Water (R13.1)	20170822.R13-6o0	20170822.R520
109 - T - 002(S)	906858	ICPMS Reg. Water (R13.1)	20170822.R13-6o0	20170822.R520