



CERTIFICATE OF ANALYSIS

Client: Mike Lavallee
Company: RDSB - Cyril Varney Public School
Address: 69 Young St
Sudbury, ON, P3E 3G5
Phone/Fax: (705) 674-3171 / (705) 761-2442
Email: lavallm@rainbowschools.ca

Work Order Number: 313195
PO #: 706LW1736503
Regulation: O.Reg. 243/07
Project #:
DWS #: 500046008
Sampled By: Mike Lavallee

Date Order Received: 8/9/2017
Arrival Temperature: 8 °C

Analysis Started: 8/14/2017
Analysis Completed: 8/15/2017

WORK ORDER SUMMARY

ANALYSES WERE PERFORMED ON THE FOLLOWING SAMPLES. THE RESULTS RELATE ONLY TO THE ITEMS TESTED.

Sample Description	Lab ID	Matrix	Type	Comments	Date Collected	Time Collected
155-T-001(S)	903934	Water	Plumbing		8/8/2017	6:00 AM
155-T-001(F)	903935	Water	Plumbing		8/8/2017	6:35 AM
155-B/F-001(S)	903936	Water	Plumbing		8/8/2017	6:03 AM
155-B/F-001(F)	903937	Water	Plumbing		8/8/2017	6:38 AM
155-F-001(S)	903938	Water	Plumbing		8/8/2017	6:05 AM
155-F-001(F)	903939	Water	Plumbing		8/8/2017	6:40 AM
155-F-002(S)	903940	Water	Plumbing		8/8/2017	6:10 AM
155-F-002(F)	903941	Water	Plumbing		8/8/2017	6:50 AM

METHODS AND INSTRUMENTATION

THE FOLLOWING METHODS WERE USED FOR YOUR SAMPLE(S):

Method	Lab	Description	Reference
ICPMS Reg. Water (R13.1)	Garson	Determination of Metals in Water by ICP/MS	Based on SW846-6020A

REPORT COMMENTS

Standing in excess of 6 hrs



TESTMARK Laboratories Ltd.

Committed to Quality and Service

CERTIFICATE OF ANALYSIS

RDSB - Cyril Varney Public School

Work Order Number: 313195

This report has been approved by:

Khaled Omari, Ph.D.
Laboratory Director



CERTIFICATE OF ANALYSIS

RDSB - Cyril Varney Public School

Work Order Number: 313195

WORK ORDER RESULTS

Sample Description	155 - T - 001(S)		155 - T - 001(F)		155 - B/F - 001(S)		155 - B/F - 001(F)			
Lab ID	903934		903935		903936		903937			
Metals	Result	MDL	Result	MDL	Result	MDL	Result	MDL	Units	Criteria: O.Reg. 243/07
Lead	0.86	0.1	0.33	0.1	<0.1	0.1	<0.1	0.1	ug/L	10

Sample Description	155 - F - 001(S)		155 - F - 001(F)		155 - F - 002(S)		155 - F - 002(F)			
Lab ID	903938		903939		903940		903941			
Metals	Result	MDL	Result	MDL	Result	MDL	Result	MDL	Units	Criteria: O.Reg. 243/07
Lead	0.51	0.1	0.3	0.1	2.53	0.1	0.7	0.1	ug/L	10

LEGEND

Dates: Dates are formatted as mm/dd/year throughout this report.

MDL: Method detection limit or minimum reporting limit.

Quality Control: All associated Quality Control data is available on request.