



## CERTIFICATE OF ANALYSIS

Client:	Mike Lavallee	Work Order Number:	313196
Company:	RDSB - Ernie Checkers Public School	PO #:	706LW1736503
Address:	69 Young StSRDSB - Westmount Avenue Public School Sudbury, ON, P3E 3G5	Regulation:	O.Reg. 243/07
Phone/Fax:	(705) 929-4787 / (705) 761-2442	Project #:	
Email:	lavallm@rainbowschools.ca	DWS #:	500039183
		Sampled By:	Mike Lavallee
Date Order Received:	8/9/2017	Analysis Started:	8/14/2017
Arrival Temperature:	20 °C	Analysis Completed:	8/17/2017

### WORK ORDER SUMMARY

ANALYSES WERE PERFORMED ON THE FOLLOWING SAMPLES. THE RESULTS RELATE ONLY TO THE ITEMS TESTED.

Sample Description	Lab ID	Matrix	Type	Comments	Date Collected	Time Collected
165-B/F-001 (S)	903942	Water	Plumbing		8/8/2017	4:45 AM
165-B/F-001 (F)	903943	Water	Plumbing		8/8/2017	5:20 AM
165-T-001 (S)	903944	Water	Plumbing		8/8/2017	4:40 AM
165-T-001 (F)	903945	Water	Plumbing		8/8/2017	5:15 AM
165-T-002 (S)	903946	Water	Plumbing		8/8/2017	4:35 AM
165-T-002 (F)	903947	Water	Plumbing		8/8/2017	5:10 AM
165-T-003 (S)	903948	Water	Plumbing		8/8/2017	4:30 AM
165-T-003 (S)	903949	Water	Plumbing		8/8/2017	5:05 AM

### METHODS AND INSTRUMENTATION

THE FOLLOWING METHODS WERE USED FOR YOUR SAMPLE(S):

Method	Lab	Description	Reference
ICPMS Reg. Water (R13.1)	Garson	Determination of Metals in Water by ICP/MS	Based on SW846-6020A

### REPORT COMMENTS

Standing in excess of 6 hrs



**TESTMARK Laboratories Ltd.**

*Committed to Quality and Service*

## CERTIFICATE OF ANALYSIS

RDSB - Ernie Checkeris Public School

Work Order Number: 313196

This report has been approved by:

Khaled Omari, Ph.D.  
Laboratory Director



## CERTIFICATE OF ANALYSIS

RDSB - Ernie Checkeris Public School

Work Order Number: 313196

### WORK ORDER RESULTS

Sample Description	165 - B/F - 001 (S)		165 - B/F - 001 (F)		165 - T - 001 (S)		165 - T - 001 (F)			
Lab ID	903942		903943		903944		903945			
Metals	Result	MDL	Result	MDL	Result	MDL	Result	MDL	Units	Criteria: O.Reg. 243/07
Lead	<0.1	0.1	<0.1	0.1	2.69	0.1	1.54	0.1	ug/L	10

  

Sample Description	165 - T - 002 (S)		165 - T - 002 (F)		165 - T - 003 (S)		165 - T - 003 (F)			
Lab ID	903946		903947		903948		903949			
Metals	Result	MDL	Result	MDL	Result	MDL	Result	MDL	Units	Criteria: O.Reg. 243/07
Lead	1.76 [1.69]	0.1	0.81	0.1	0.17	0.1	0.17	0.1	ug/L	10

### LEGEND

Dates: Dates are formatted as mm/dd/year throughout this report.

MDL: Method detection limit or minimum reporting limit.

[ ]: Results for laboratory replicates are shown in square brackets immediately below the associated sample result for ease of comparison.

Quality Control: All associated Quality Control data is available on request.