



**TESTMARK Laboratories Ltd.**

Committed to Quality and Service

## CERTIFICATE OF ANALYSIS

Client: Mike Lavallee  
Company: RDSB - Larchwood Public School  
Address: 69 Young St.  
Sudbury, ON, P3E 3G5  
Phone/Fax: (705) 929-4787 / (705) 761-2442  
Email: lavallm@rainbowschools.ca

Work Order Number: 319548  
PO #: 706LW1736503  
Regulation: O.Reg. 243/07  
Project #:  
DWS #: 500046086  
Sampled By: Jason C

Date Order Received: 10/20/2017  
Arrival Temperature: 20 °C

Analysis Started: 10/27/2017  
Analysis Completed: 10/30/2017

### WORK ORDER SUMMARY

ANALYSES WERE PERFORMED ON THE FOLLOWING SAMPLES. THE RESULTS RELATE ONLY TO THE ITEMS TESTED.

Sample Description	Lab ID	Matrix	Type	Comments	Date Collected	Time Collected
Standing - 163-T-003	1018245	Treated Water	Plumbing		10/20/2017	6:30 AM
Flushed - 163-T-003	1018246	Treated Water	Plumbing		10/20/2017	7:05 AM

### METHODS AND INSTRUMENTATION

THE FOLLOWING METHODS WERE USED FOR YOUR SAMPLE(S):

Method	Lab	Description	Reference
ICPMS Reg. Water (R13.1)	Garson	Determination of Metals in Water by ICP/MS	Based on SW846-6020A

This report has been approved by:

Khaled Omari, Ph.D.  
Laboratory Director



## CERTIFICATE OF ANALYSIS

RDSB - Larchwood Public School

Work Order Number: 319548

### WORK ORDER RESULTS

Sample Description	Standing - 163 - T - 003		Flushed - 163 - T - 003			
Lab ID	1018245		1018246			
Metals	Result	MDL	Result	MDL	Units	Criteria: O.Reg. 243/07
Lead	9.97	0.1	4.09	0.1	ug/L	10

### LEGEND

Dates: Dates are formatted as mm/dd/year throughout this report.

MDL: Method detection limit or minimum reporting limit.

Quality Control: All associated Quality Control data is available on request.