



**TESTMARK Laboratories Ltd.**

Committed to Quality and Service

## CERTIFICATE OF ANALYSIS

Client: Mike Lavallee  
Company: RDSB - Levack Public School  
Address: 69 Young St.  
Sudbury, ON, P3E 3G5  
Phone/Fax: (705) 929-4787 / (705) 761-2442  
Email: lavallm@rainbowschools.ca

Work Order Number: 319549  
PO #: 706LW1736503  
Regulation: O.Reg. 243/07  
Project #:  
DWS #: 500045787  
Sampled By: Helen Tremblay

Date Order Received: 10/20/2017  
Arrival Temperature: 20 °C

Analysis Started: 10/27/2017  
Analysis Completed: 10/30/2017

### WORK ORDER SUMMARY

ANALYSES WERE PERFORMED ON THE FOLLOWING SAMPLES. THE RESULTS RELATE ONLY TO THE ITEMS TESTED.

Sample Description	Lab ID	Matrix	Type	Comments	Date Collected	Time Collected
Standing - 129-T-005	1018251	Treated Water	Plumbing		10/20/2017	6:30 AM
Flushed - 129-T-005	1018252	Treated Water	Plumbing		10/20/2017	7:05 AM

### METHODS AND INSTRUMENTATION

THE FOLLOWING METHODS WERE USED FOR YOUR SAMPLE(S):

Method	Lab	Description	Reference
ICPMS Reg. Water (R13.1)	Garson	Determination of Metals in Water by ICP/MS	Based on SW846-6020A

This report has been approved by:

Khaled Omari, Ph.D.  
Laboratory Director



## CERTIFICATE OF ANALYSIS

RDSB - Levack Public School

Work Order Number: 319549

### WORK ORDER RESULTS

Sample Description	Standing - 129 - T - 005		Flushed - 129 - T - 005		Units	Criteria: O.Reg. 243/07
Lab ID	1018251		1018252			
Metals	Result	MDL	Result	MDL		
Lead	0.74	0.1	0.14	0.1	ug/L	10

### LEGEND

Dates: Dates are formatted as mm/dd/year throughout this report.

MDL: Method detection limit or minimum reporting limit.

Quality Control: All associated Quality Control data is available on request.