



TESTMARK Laboratories Ltd.

Committed to Quality and Service

CERTIFICATE OF ANALYSIS

Client: Mark Bocy
Company: RDSB - Lockerby Composite School
Address: 69 Young St
Sudbury, ON, P3E 3G5
Phone/Fax: (705) 690-0323 / (705) 671-2442
Email: bocym@rainbowschools.ca

Work Order Number: 318827
PO #: 706LW1736503
Regulation: O.Reg. 243/07
Project #:
DWS #: 500040314
Sampled By:

Date Order Received: 10/13/2017
Arrival Temperature: 15 °C

Analysis Started: 10/17/2017
Analysis Completed: 10/18/2017

WORK ORDER SUMMARY

ANALYSES WERE PERFORMED ON THE FOLLOWING SAMPLES. THE RESULTS RELATE ONLY TO THE ITEMS TESTED.

Sample Description	Lab ID	Matrix	Type	Comments	Date Collected	Time Collected
SINK 11-C STANDING	1015609	Treated Water	Plumbing		10/13/2017	6:30 AM
SINK 11-C FLUSHING	1015610	Treated Water	Plumbing		10/13/2017	7:05 AM

METHODS AND INSTRUMENTATION

THE FOLLOWING METHODS WERE USED FOR YOUR SAMPLE(S):

Method	Lab	Description	Reference
ICPMS Reg. Water (R13.1)	Garson	Determination of Metals in Water by ICP/MS	Based on SW846-6020A

REPORT COMMENTS

SINK 11-C ROOM 223

This report has been approved by:

Khaled Omari, Ph.D.
Laboratory Director



CERTIFICATE OF ANALYSIS

RDSB - Lockerby Composite School

Work Order Number: 318827

WORK ORDER RESULTS

Sample Description	SINK 11 - C STANDING		SINK 11 - C FLUSHING			
Lab ID	1015609		1015610			
Metals	Result	MDL	Result	MDL	Units	Criteria: O.Reg. 243/07
Lead	0.4	0.1	0.12	0.1	ug/L	10

LEGEND

Dates: Dates are formatted as mm/dd/year throughout this report.

MDL: Method detection limit or minimum reporting limit.

Quality Control: All associated Quality Control data is available on request.

LCL: Lower Control Limit.

UCL: Upper Control Limit.

QAQCID: This is a unique reference to the quality control data set used to generate the reported value. Contact our lab for this information, as it is traceable through our LIMS.



CERTIFICATE OF ANALYSIS

RDSB - Lockerby Composite School

Work Order Number: 318827

QUALITY CONTROL DATA

THIS SECTION REPORTS QC RESULTS ASSOCIATED WITH THE TEST BATCH; THESE ARE NOT YOUR SAMPLE RESULTS.
QAQC details include only values where sufficient sample data allowed measurement.

Metals							
Method Blank							
Parameter	MDL	Units	LCL	Result	UCL	QAQCID	
Lead	1	ug/L	0	<1	1	20171017.R13-6o3	
Positive Control							
Parameter	MDL	Units	LCL	Result	UCL	QAQCID	
Lead	N/A	%	80	100	120	20171017.R13-6o3	
Reference Sample							
Parameter	MDL	Units	LCL	Result	UCL	QAQCID	
Lead	N/A	% Rec	80	96.2	120	20171017.R13-6o3	
Sample Spike							
Parameter	MDL	Units	LCL	Result	UCL	QAQCID	
Lead	N/A	% Rec	70	90.7	130	20171017.R13-6o3	

THIS INDEX SHOWS HOW YOUR SAMPLES ARE ASSOCIATED TO THE CONTROLS INCLUDED IN THE IDENTIFIED BATCHES.

Sample Description	Lab ID	Method	QAQCID	Prep QAQCID
SINK 11 - C FLUSHING	1015610	ICPMS Reg. Water (R13.1)	20171017.R13-6o3	20171017.A52P
SINK 11 - C STANDING	1015609	ICPMS Reg. Water (R13.1)	20171017.R13-6o3	20171017.A52P