



TESTMARK Laboratories Ltd.

Committed to Quality and Service

CERTIFICATE OF ANALYSIS

Client: Mark Bocy
Company: RDSB - Lockerby Composite School
Address: 69 Young St
Sudbury, ON, P3E 3G5
Phone/Fax: (705) 690-0323 / (705) 671-2442
Email: bocym@rainbowschools.ca

Work Order Number: 318829
PO #: 706LW1736503
Regulation: O.Reg. 243/07
Project #:
DWS #: 500040314
Sampled By: Lisa P

Date Order Received: 10/13/2017
Arrival Temperature: 15 °C

Analysis Started: 10/17/2017
Analysis Completed: 10/18/2017

WORK ORDER SUMMARY

ANALYSES WERE PERFORMED ON THE FOLLOWING SAMPLES. THE RESULTS RELATE ONLY TO THE ITEMS TESTED.

Sample Description	Lab ID	Matrix	Type	Comments	Date Collected	Time Collected
Fountain 1 STANDING	1015613	Treated Water	Plumbing		10/13/2017	6:30 AM
Fountain 1 FLUISHING	1015614	Treated Water	Plumbing		10/13/2017	7:05 AM

METHODS AND INSTRUMENTATION

THE FOLLOWING METHODS WERE USED FOR YOUR SAMPLE(S):

Method	Lab	Description	Reference
ICPMS Reg. Water (R13.1)	Garson	Determination of Metals in Water by ICP/MS	Based on SW846-6020A

REPORT COMMENTS

Fountain 1 By Room 159

This report has been approved by:

Khaled Omari, Ph.D.
Laboratory Director



CERTIFICATE OF ANALYSIS

RDSB - Lockerby Composite School

Work Order Number: 318829

WORK ORDER RESULTS

Sample Description	Fountain 1 STANDING		Fountain 1 FLUSHING			
Lab ID	1015613		1015614			
Metals	Result	MDL	Result	MDL	Units	Criteria: O.Reg. 243/07
Lead	<0.1	0.1	<0.1	0.1	ug/L	10

LEGEND

Dates: Dates are formatted as mm/dd/year throughout this report.

MDL: Method detection limit or minimum reporting limit.

Quality Control: All associated Quality Control data is available on request.

LCL: Lower Control Limit.

UCL: Upper Control Limit.

QAQCID: This is a unique reference to the quality control data set used to generate the reported value. Contact our lab for this information, as it is traceable through our LIMS.



CERTIFICATE OF ANALYSIS

RDSB - Lockerby Composite School

Work Order Number: 318829

QUALITY CONTROL DATA

THIS SECTION REPORTS QC RESULTS ASSOCIATED WITH THE TEST BATCH; THESE ARE NOT YOUR SAMPLE RESULTS.
QAQC details include only values where sufficient sample data allowed measurement.

Metals							
Method Blank							
Parameter	MDL	Units	LCL	Result	UCL	QAQCID	
Lead	1	ug/L	0	<1	1	20171017.R13-6o4	
Positive Control							
Parameter	MDL	Units	LCL	Result	UCL	QAQCID	
Lead	N/A	%	80	103	120	20171017.R13-6o4	
Reference Sample							
Parameter	MDL	Units	LCL	Result	UCL	QAQCID	
Lead	N/A	% Rec	80	97.4	120	20171017.R13-6o4	
Sample Spike							
Parameter	MDL	Units	LCL	Result	UCL	QAQCID	
Lead	N/A	% Rec	70	86.3	130	20171017.R13-6o4	

THIS INDEX SHOWS HOW YOUR SAMPLES ARE ASSOCIATED TO THE CONTROLS INCLUDED IN THE IDENTIFIED BATCHES.

Sample Description	Lab ID	Method	QAQCID	Prep QAQCID
Fountain 1 FLUISHING	1015614	ICPMS Reg. Water (R13.1)	20171017.R13-6o4	20171017.A52Q
Fountain 1 STANDING	1015613	ICPMS Reg. Water (R13.1)	20171017.R13-6o4	20171017.A52Q