



## CERTIFICATE OF ANALYSIS

Client: Mark Bocy  
Company: RDSB - Lockerby Composite School  
Address: 69 Young St  
Sudbury, ON, P3E 3G5  
Phone/Fax: (705) 690-0323 / (705) 671-2442  
Email: bocym@rainbowschools.ca;  
lavallm@rainbowschools.ca

Work Order Number: 309020  
PO #: 706LW1736503  
Regulation: O.Reg. 243/07  
Project #:  
DWS #: 500040314  
Sampled By: Lisa P

Date Order Received: 6/20/2017  
Arrival Temperature: 18 °C

Analysis Started: 6/22/2017  
Analysis Completed: 6/23/2017

### WORK ORDER SUMMARY

ANALYSES WERE PERFORMED ON THE FOLLOWING SAMPLES. THE RESULTS RELATE ONLY TO THE ITEMS TESTED.

Sample Description	Lab ID	Matrix	Type	Comments	Date Collected	Time Collected
Sink 1-Room 166c STANDING	888956	Water	Plumbing		6/20/2017	6:30 AM
Sink 1-Room 166c Flushing	888957	Water	Plumbing		6/20/2017	7:05 AM

### METHODS AND INSTRUMENTATION

THE FOLLOWING METHODS WERE USED FOR YOUR SAMPLE(S):

Method	Lab	Description	Reference
ICPMS Reg. Water	Garson	Determination of Metals in Water by ICP/MS	Based on SW846-6020A

This report has been approved by:

Khaled Omari, Ph.D.  
Laboratory Director



## CERTIFICATE OF ANALYSIS

RDSB - Lockerby Composite School

Work Order Number: 309020

### WORK ORDER RESULTS

Sample Description	Sink 1 - Room 166c STANDING		Sink 1 - Room 166c Flushing			
Lab ID	888956		888957			
Metals	Result	MDL	Result	MDL	Units	Criteria: O.Reg. 243/07
Lead	0.96	0.1	0.19	0.1	ug/L	10

### LEGEND

Dates: Dates are formatted as mm/dd/year throughout this report.

MDL: Method detection limit or minimum reporting limit.

Quality Control: All associated Quality Control data is available on request.