



TESTMARK Laboratories Ltd.

Committed to Quality and Service

CERTIFICATE OF ANALYSIS

Client: Mark Bocy
Company: RDSB - Lockerby Composite School
Address: 69 Young St
Sudbury, ON, P3E 3G5
Phone/Fax: (705) 674-3171 / (705) 761-2442
Email: bocym@rainbowschools.ca;
lavallm@rainbowschools.ca

Work Order Number: 309024
PO #: 706LW1736503
Regulation: O.Reg. 243/07
Project #:
DWS #: 500040314
Sampled By: Lisa P

Date Order Received: 6/20/2017
Arrival Temperature: 18 °C

Analysis Started: 6/23/2017
Analysis Completed: 6/26/2017

WORK ORDER SUMMARY

ANALYSES WERE PERFORMED ON THE FOLLOWING SAMPLES. THE RESULTS RELATE ONLY TO THE ITEMS TESTED.

Sample Description	Lab ID	Matrix	Type	Comments	Date Collected	Time Collected
S-2-167-B STANDING	888963	Water	Plumbing		6/20/2017	6:00 AM
S-2-167-B Flushing	888964	Water	Plumbing		6/20/2017	6:35 AM

METHODS AND INSTRUMENTATION

THE FOLLOWING METHODS WERE USED FOR YOUR SAMPLE(S):

Method	Lab	Description	Reference
ICPMS Reg. Water	Garson	Determination of Metals in Water by ICP/MS	Based on SW846-6020A

This report has been approved by:

Khaled Omari, Ph.D.
Laboratory Director



CERTIFICATE OF ANALYSIS

RDSB - Lockerby Composite School

Work Order Number: 309024

WORK ORDER RESULTS

Sample Description	S - 2 - 167 - B STANDING		S - 2 - 167 - B Flushing			
Lab ID	888963		888964			
Metals	Result	MDL	Result	MDL	Units	Criteria: O.Reg. 243/07
Lead	1.73	0.1	0.17	0.1	ug/L	10

LEGEND

Dates: Dates are formatted as mm/dd/year throughout this report.

MDL: Method detection limit or minimum reporting limit.

Quality Control: All associated Quality Control data is available on request.

LCL: Lower Control Limit.

UCL: Upper Control Limit.

QAQCID: This is a unique reference to the quality control data set used to generate the reported value. Contact our lab for this information, as it is traceable through our LIMS.



CERTIFICATE OF ANALYSIS

RDSB - Lockerby Composite School

Work Order Number: 309024

QUALITY CONTROL DATA

THIS SECTION REPORTS QC RESULTS ASSOCIATED WITH THE TEST BATCH; THESE ARE NOT YOUR SAMPLE RESULTS.
QAQC details include only values where sufficient sample data allowed measurement.

Metals							
Method Blank							
Parameter	MDL	Units	LCL	Result	UCL	QAQCID	
Lead	1	ug/L	0	<1	1	20170625.R13-5o	
Positive Control							
Parameter	MDL	Units	LCL	Result	UCL	QAQCID	
Lead	N/A	%	80	95.9	120	20170625.R13-5o	
Reference Sample							
Parameter	MDL	Units	LCL	Result	UCL	QAQCID	
Lead	N/A	% Rec	80	102	120	20170625.R13-5o	
Sample Spike							
Parameter	MDL	Units	LCL	Result	UCL	QAQCID	
Lead	N/A	% Rec	70	94.7	130	20170625.R13-5o	

THIS INDEX SHOWS HOW YOUR SAMPLES ARE ASSOCIATED TO THE CONTROLS INCLUDED IN THE IDENTIFIED BATCHES.

Sample Description	Lab ID	Method	QAQCID	Prep QAQCID
S - 2 - 167 - B Flushing	888964	ICPMS Reg. Water	20170625.R13-5o	20170623.R52P
S - 2 - 167 - B STANDING	888963	ICPMS Reg. Water	20170625.R13-5o	20170623.R52P