



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500039092

Project : PO#017470

04-August-2016

OCWA-Espanola (Monetville Public School - O.Reg243)

Attn : Keith Stringer

Date Rec. : 29 July 2016

LR Report: CA17269-JUL16

87B Centre St.
Espanola, ON
P5E 1S4,

Copy: #1

Phone: 705-869-5578

Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Sampled By	Temperature Upon Receipt °C	Free Chlorine mg/L	Lead ug/L
1: Analysis Start Date			---		03-Aug-16
2: Analysis Start Time			---		14:00
3: Analysis Approval Date			--		03-Aug-16
4: Analysis Approval Time			--		14:45
5: MAC			--		10
6: MDL			---		0.01
7: TAP Standing Teacher's Kitchen Sink	26-Jul-16 09:30	Patricia Mathieu	17.0	1.27	4.31
8: TAP Flushed Teacher's Kitchen Sink	26-Jul-16 10:07	Patricia Mathieu	17.0	1.34	0.26

MAC - Maximum Acceptable Concentration

MDL - SGS Method Detection Limit

Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Carrie Greenlaw
Project Specialist
Environmental Services, Analytical