



TESTMARK Laboratories Ltd.

Committed to Quality and Service

CERTIFICATE OF ANALYSIS

Client: Mike Lavallee
Company: RDSB - C.R. Judd Public School
Address: 69 Young St.
Sudbury, ON, P3E 3G5
Phone/Fax: (705) 674-3171 / (705) 761-2442
Email: lavallm@rainbowschools.ca

Work Order Number: 347097
PO #: 706LW1736503
Regulation: O.Reg. 243/07
Project #:
DWS #: 500040301
Sampled By: Mike Lavallee

Date Order Received: 6/18/2018
Arrival Temperature: 5 °C

Analysis Started: 6/20/2018
Analysis Completed: 6/21/2018

WORK ORDER SUMMARY

ANALYSES WERE PERFORMED ON THE FOLLOWING SAMPLES. THE RESULTS RELATE ONLY TO THE ITEMS TESTED.

Sample Description	Lab ID	Matrix	Type	Comments	Date Collected	Time Collected
125-F-02 (S)	1352770	Water	Plumbing		6/16/2018	8:15 AM
125-F-02 (F)	1352771	Water	Plumbing		6/16/2018	8:50 AM
125-F-05 (S)	1352772	Water	Plumbing		6/16/2018	8:10 AM
125-F-05 (F)	1352773	Water	Plumbing		6/16/2018	8:45 AM
125-F-06 (S)	1352774	Water	Plumbing		6/16/2018	8:10 AM
125-F-06 (F)	1352775	Water	Plumbing		6/16/2018	8:45 AM
125-F-04 (S)	1352776	Water	Plumbing		6/16/2018	8:04 AM
125-F-04 (F)	1352777	Water	Plumbing		6/16/2018	8:39 AM
125-T-02 (S)	1352778	Water	Plumbing		6/16/2018	8:04 AM
125-T-02 (F)	1352779	Water	Plumbing		6/16/2018	8:39 AM
125-T-03 (S)	1352780	Water	Plumbing		6/16/2018	8:04 AM
125-T-03 (F)	1352781	Water	Plumbing		6/16/2018	8:39 AM
125-T-04 (S)	1352782	Water	Plumbing		6/16/2018	8:04 AM
125-T-04 (F)	1352783	Water	Plumbing		6/16/2018	8:39 AM

METHODS AND INSTRUMENTATION

THE FOLLOWING METHODS WERE USED FOR YOUR SAMPLE(S):

Method	Lab	Description	Reference
ICPMS Reg. Water (R13.1)	Garson	Determination of Metals in Water by ICP/MS	Modified from SW846-6020A



TESTMARK Laboratories Ltd.

Committed to Quality and Service

CERTIFICATE OF ANALYSIS

RDSB - C.R. Judd Public School

Work Order Number: 347097

REPORT COMMENTS

Water standing in excess of 6hrs, as per O.reg. 243.

This report has been approved by:

Khaled Omari, Ph.D.
Laboratory Director

CERTIFICATE OF ANALYSIS

RDSB - C.R. Judd Public School

Work Order Number: 347097

WORK ORDER RESULTS

Sample Description	125 - F - 02 (S)		125 - F - 02 (F)		125 - F - 05 (S)		125 - F - 05 (F)		Units	Criteria: O.Reg. 243/07
Lab ID	1352770		1352771		1352772		1352773			
Metals	Result	MDL	Result	MDL	Result	MDL	Result	MDL		
Lead	<0.1 [<0.1]	0.1	<0.1	0.1	0.43	0.1	0.16	0.1	ug/L	10

Sample Description	125 - F - 06 (S)		125 - F - 06 (F)		125 - F - 04 (S)		125 - F - 04 (F)		Units	Criteria: O.Reg. 243/07
Lab ID	1352774		1352775		1352776		1352777			
Metals	Result	MDL	Result	MDL	Result	MDL	Result	MDL		
Lead	1.25	0.1	0.36	0.1	0.27	0.1	<0.1	0.1	ug/L	10

Sample Description	125 - T - 02 (S)		125 - T - 02 (F)		125 - T - 03 (S)		125 - T - 03 (F)		Units	Criteria: O.Reg. 243/07
Lab ID	1352778		1352779		1352780		1352781			
Metals	Result	MDL	Result	MDL	Result	MDL	Result	MDL		
Lead	0.77	0.1	0.22	0.1	0.46	0.1	0.1	0.1	ug/L	10

Sample Description	125 - T - 04 (S)		125 - T - 04 (F)		Units	Criteria: O.Reg. 243/07
Lab ID	1352782		1352783			
Metals	Result	MDL	Result	MDL		
Lead	0.52	0.1	0.24	0.1	ug/L	10

LEGEND

Dates: Dates are formatted as mm/dd/year throughout this report.

MDL: Method detection limit or minimum reporting limit.

[]: Results for laboratory replicates are shown in square brackets immediately below the associated sample result for ease of comparison.

Quality Control: All associated Quality Control data is available on request.