



**TESTMARK Laboratories Ltd.**

Committed to Quality and Service

## CERTIFICATE OF ANALYSIS

Client: Mike Lavallee  
Company: RDSB - Levack Public School  
Address: 69 Young St.  
Sudbury, ON, P3E 3G5  
Phone/Fax: (705) 674-3171 / (705) 761-2442  
Email: lavallm@rainbowschools.ca

Work Order Number: 347093  
PO #: 706LW1736503  
Regulation: O.Reg. 243/07  
Project #:  
DWS #: 500045787  
Sampled By: Mike Lavallee

Date Order Received: 6/18/2018  
Arrival Temperature: 5 °C

Analysis Started: 6/20/2018  
Analysis Completed: 6/21/2018

### WORK ORDER SUMMARY

ANALYSES WERE PERFORMED ON THE FOLLOWING SAMPLES. THE RESULTS RELATE ONLY TO THE ITEMS TESTED.

Sample Description	Lab ID	Matrix	Type	Comments	Date Collected	Time Collected
129-B/F-01 (S)	1352741	Water	Plumbing	SAMPLE CONTAINED RESULT EXCEEDENCES.	6/17/2018	8:04 AM
129-B/F-01 (F)	1352742	Water	Plumbing		6/17/2018	8:39 AM
129-F-02-A (S)	1352743	Water	Plumbing		6/17/2018	7:55 AM
129-F-02-A (F)	1352744	Water	Plumbing		6/17/2018	8:30 AM
129-F-02-B (S)	1352745	Water	Plumbing		6/17/2018	7:55 AM
129-F-02-B (F)	1352746	Water	Plumbing		6/17/2018	8:30 AM
129-F-03 (S)	1352747	Water	Plumbing		6/17/2018	7:55 AM
129-F-03 (F)	1352748	Water	Plumbing		6/17/2018	8:30 AM
129-T-05 (S)	1352749	Water	Plumbing		6/17/2018	8:03 AM
129-T-05 (F)	1352750	Water	Plumbing		6/17/2018	8:38 AM

### METHODS AND INSTRUMENTATION

THE FOLLOWING METHODS WERE USED FOR YOUR SAMPLE(S):

Method	Lab	Description	Reference
ICPMS Reg. Water (R13.1)	Garson	Determination of Metals in Water by ICP/MS	Modified from SW846-6020A

### REPORT COMMENTS

Sample 1352741 lead exceedance reported. 06/21/18 DC



**TESTMARK Laboratories Ltd.**

*Committed to Quality and Service*

## CERTIFICATE OF ANALYSIS

RDSB - Levack Public School

Work Order Number: 347093

This report has been approved by:

Khaled Omari, Ph.D.  
Laboratory Director

## CERTIFICATE OF ANALYSIS

RDSB - Levack Public School

Work Order Number: 347093

### WORK ORDER RESULTS

Sample Description	129 - B/F - 01 (S)		129 - B/F - 01 (F)		129 - F - 02 - A (S)		129 - F - 02 - A (F)			
Lab ID	1352741		1352742		1352743		1352744			
Metals	Result	MDL	Result	MDL	Result	MDL	Result	MDL	Units	Criteria: O.Reg. 243/07
Lead	12.3	0.1	4.89	0.1	1.75	0.1	0.42	0.1	ug/L	10

  

Sample Description	129 - F - 02 - B (S)		129 - F - 02 - B (F)		129 - F - 03 (S)		129 - F - 03 (F)			
Lab ID	1352745		1352746		1352747		1352748			
Metals	Result	MDL	Result	MDL	Result	MDL	Result	MDL	Units	Criteria: O.Reg. 243/07
Lead	2.51	0.1	0.39	0.1	0.83	0.1	0.91	0.1	ug/L	10

  

Sample Description	129 - T - 05 (S)		129 - T - 05 (F)			
Lab ID	1352749		1352750			
Metals	Result	MDL	Result	MDL	Units	Criteria: O.Reg. 243/07
Lead	1.42	0.1	0.42	0.1	ug/L	10

### LEGEND

Dates: Dates are formatted as mm/dd/year throughout this report.

MDL: Method detection limit or minimum reporting limit.

Quality Control: All associated Quality Control data is available on request.