



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500039092

Project : PO#017470

28-September-2018

OCWA-Espanola (Monetville Public School - O.Reg243)

Attn : Keith Stringer

Date Rec. : 22 September 2018

LR Report: CA16640-SEP18

87B Centre St.
Espanola, ON
P5E 1S4, Canada

Copy: #1

Phone: 705-869-5578

Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Sampled By	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date			---	28-Sep-18
2: Analysis Start Time			---	10:33
3: Analysis Completed Date			---	28-Sep-18
4: Analysis Completed Time			---	11:42
5: MAC			---	10
6: MDL			---	0.01
7: TAP Standing Room 309	21-Sep-18 07:46	Lance Myke	17.0	29.8 MAC
8: TAP Flushed Room 309	21-Sep-18 08:22	Lance Myke	17.0	4.59

MAC - Maximum Acceptable Concentration

MDL - SGS Method Detection Limit

MAC - (ADVERSE) Above Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
ug/L	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Carrie Greenlaw
Project Specialist
Environmental Services, Analytical