



TESTMARK Laboratories Ltd.

Committed to Quality and Service

CERTIFICATE OF ANALYSIS

Client:	Lisa Polano	Work Order Number:	374910
Company:	RDSB - Valley View P.S.	PO #:	
Address:	69 Young St. Sudbury, ON, P3E 3G5	Regulation:	O.Reg. 243/07
Phone/Fax:	(705) 674-3171 / (705) 671-2442	Project #:	
Email:	polanol@rainbowschools.ca	DWS #:	500044448
		Sampled By:	Lisa Polano
Date Order Received:	6/14/2019	Analysis Started:	6/19/2019
Arrival Temperature:	14 °C	Analysis Completed:	6/20/2019

WORK ORDER SUMMARY

ANALYSES WERE PERFORMED ON THE FOLLOWING SAMPLES. THE RESULTS RELATE ONLY TO THE ITEMS TESTED.

Sample Description	Lab ID	Matrix	Type	Comments	Date Collected	Time Collected
Standing F-003-A by 205	1447425	Water	Plumbing		6/13/2019	6:00 AM
Flushed F-003-A by 205	1447426	Water	Plumbing		6/13/2019	6:35 AM
St F-004-A by 219	1447427	Water	Plumbing		6/13/2019	6:05 AM
FI F-004-A by 219	1447428	Water	Plumbing		6/13/2019	6:40 AM

METHODS AND INSTRUMENTATION

THE FOLLOWING METHODS WERE USED FOR YOUR SAMPLE(S):

Method	Lab	Description	Reference
ICPMS Reg. Water (A13)	Garson	Determination of Metals in Water by ICP/MS	Modified from SW846-6020A



TESTMARK Laboratories Ltd.

Committed to Quality and Service

CERTIFICATE OF ANALYSIS

RDSB - Valley View P.S.

Work Order Number: 374910

This report has been approved by:

Khaled Omari, Ph.D.

Laboratory Director



CERTIFICATE OF ANALYSIS

RDSB - Valley View P.S.

Work Order Number: 374910

WORK ORDER RESULTS

Sample Description	Standing F - 003 - A by 205		Flushed F - 003 - A by 205		St F - 004 - A by 219		FI F - 004 - A by 219			
Lab ID	1447425		1447426		1447427		1447428			
Metals	Result	MDL	Result	MDL	Result	MDL	Result	MDL	Units	Criteria: O.Reg. 243/07
Lead	<0.1	0.1	<0.1	0.1	<0.1	0.1	<0.1	0.1	ug/L	10

LEGEND

Dates: Dates are formatted as mm/dd/year throughout this report.

MDL: Method detection limit or minimum reporting limit.

Quality Control: All associated Quality Control data is available on request.

LCL: Lower Control Limit.

UCL: Upper Control Limit.

QAQCID: This is a unique reference to the quality control data set used to generate the reported value. Contact our lab for this information, as it is traceable through our LIMS.

Exceedences: HIGHLIGHTED CELLS INDICATE THAT THE RESULT EXCEEDS A REGULATORY LIMIT. CALCULATED UNCERTAINTY ESTIMATIONS ARE NOT APPLIED FOR DETERMINING SAMPLE EXCEEDANCES.

Benzo(b)fluoranthene: Results for benzo(b)fluoranthene may include contributions from benzo(j)fluoranthene.

Field Data: Reports containing Field Parameters represent data that has been collected and provided by the client. Testmark is not responsible for the validity of this data which may be used in subsequent calculations.

Sample Condition Deviations: A noted sample condition deviation may affect the validity of the result.



CERTIFICATE OF ANALYSIS

RDSB - Valley View P.S.

Work Order Number: 374910

QUALITY CONTROL DATA

THIS SECTION REPORTS QC RESULTS ASSOCIATED WITH THE TEST BATCH; THESE ARE NOT YOUR SAMPLE RESULTS.
QAQC details include only values where sufficient sample data allowed measurement.

Metals

Method Blank: LRB-6 (Blank- µg/L) (6)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	1	ug/L	0	<1	1	20190620.A13.1B

Positive Control: LFB-7 (N 100 µg/L) (7)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	N/A	%	80	86.2	120	20190620.A13.1B

Reference Sample: CRM-12 (EP-L-3) (12)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	1	ug/L	3.65	3.87	4.35	20190620.A13.1B

Sample Replicate: % RPD (4)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	N/A	%	0	0	20	20190620.A13.1B

Sample Spike: LFMS-9 (N 100 µg/L) (9)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	N/A	% Rec	70	92.2	130	20190620.A13.1B

THIS INDEX SHOWS HOW YOUR SAMPLES ARE ASSOCIATED TO THE CONTROLS INCLUDED IN THE IDENTIFIED BATCHES.

Sample Description	Lab ID	Method	QAQCID	Prep QAQCID
Fl F - 004 - A by 219	1447428	ICPMS Reg. Water (A13)	20190620.A13.1B	20190619.A520
Flushed F - 003 - A by 205	1447426	ICPMS Reg. Water (A13)	20190620.A13.1B	20190619.A520
St F - 004 - A by 219	1447427	ICPMS Reg. Water (A13)	20190620.A13.1B	20190619.A520
Standing F - 003 - A by 205	1447425	ICPMS Reg. Water (A13)	20190620.A13.1B	20190619.A520