



CERTIFICATE OF ANALYSIS

Client:	Lisa Polano	Work Order Number:	375530
Company:	RDSB - Redwood Acres Public School	PO #:	
Address:	69 Young St. Sudbury, ON, P3E 3G5	Regulation:	O.Reg. 243/07
Phone/Fax:	(705) 674-3171 / (705) 761-2442	Project #:	
Email:	polanol@rainbowschools.ca	DWS #:	500046099
		Sampled By:	Jeanmarc Lacher
Date Order Received:	6/19/2019	Analysis Started:	6/23/2019
Arrival Temperature:	15 °C	Analysis Completed:	6/24/2019

WORK ORDER SUMMARY

ANALYSES WERE PERFORMED ON THE FOLLOWING SAMPLES. THE RESULTS RELATE ONLY TO THE ITEMS TESTED.

Sample Description	Lab ID	Matrix	Type	Comments	Date Collected	Time Collected
Standing - Room 1 F 005	1449750	Water	Plumbing		6/19/2019	6:30 AM
Flushed - Room 1 F 005	1449751	Water	Plumbing		6/19/2019	7:05 AM

METHODS AND INSTRUMENTATION

THE FOLLOWING METHODS WERE USED FOR YOUR SAMPLE(S):

Method	Lab	Description	Reference
ICPMS Reg. Water (A13)	Garson	Determination of Metals in Water by ICP/MS	Modified from SW846-6020A

This report has been approved by:

Khaled Omari, Ph.D.
Laboratory Director



CERTIFICATE OF ANALYSIS

RDSB - Redwood Acres Public School

Work Order Number: 375530

WORK ORDER RESULTS

Sample Description	Standing - Room 1 F 005		Flushed - Room 1 F 005			
Lab ID	1449750		1449751			
Metals	Result	MDL	Result	MDL	Units	Criteria: O.Reg. 243/07
Lead	0.6	0.1	0.3	0.1	ug/L	10

LEGEND

Dates: Dates are formatted as mm/dd/year throughout this report.

MDL: Method detection limit or minimum reporting limit.

Quality Control: All associated Quality Control data is available on request.

LCL: Lower Control Limit.

UCL: Upper Control Limit.

QAQCID: This is a unique reference to the quality control data set used to generate the reported value. Contact our lab for this information, as it is traceable through our LIMS.

Exceedences: HIGHLIGHTED CELLS INDICATE THAT THE RESULT EXCEEDS A REGULATORY LIMIT. CALCULATED UNCERTAINTY ESTIMATIONS ARE NOT APPLIED FOR DETERMINING SAMPLE EXCEEDANCES.

Benzo(b)fluoranthene: Results for benzo(b)fluoranthene may include contributions from benzo(j)fluoranthene.

Field Data: Reports containing Field Parameters represent data that has been collected and provided by the client. Testmark is not responsible for the validity of this data which may be used in subsequent calculations.

Sample Condition Deviations: A noted sample condition deviation may affect the validity of the result.



CERTIFICATE OF ANALYSIS

RDSB - Redwood Acres Public School

Work Order Number: 375530

QUALITY CONTROL DATA

THIS SECTION REPORTS QC RESULTS ASSOCIATED WITH THE TEST BATCH; THESE ARE NOT YOUR SAMPLE RESULTS.
QAQC details include only values where sufficient sample data allowed measurement.

Metals

Method Blank: LRB-6 (Blank- µg/L) (6)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	1	ug/L	0	<1	1	20190624.A13.1G

Positive Control: LFB-7 (N 100 µg/L) (7)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	N/A	%	80	88.8	120	20190624.A13.1G

Reference Sample: CRM-12 (EP-L-3) (12)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	1	ug/L	3.65	3.69	4.35	20190624.A13.1G

Sample Spike: LFMS-9 (N 100 µg/L) (9)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	N/A	% Rec	70	86.9	130	20190624.A13.1G

THIS INDEX SHOWS HOW YOUR SAMPLES ARE ASSOCIATED TO THE CONTROLS INCLUDED IN THE IDENTIFIED BATCHES.

Sample Description	Lab ID	Method	QAQCID	Prep QAQCID
Flushed - Room 1 F 005	1449751	ICPMS Reg. Water (A13)	20190624.A13.1G	20190623.A52E
Standing - Room 1 F 005	1449750	ICPMS Reg. Water (A13)	20190624.A13.1G	20190623.A52E