



CERTIFICATE OF ANALYSIS

Client:	Lisa Polano	Work Order Number:	382509
Company:	RDSB - Jean Hansen	PO #:	
Address:	408 Wembley Drive Sudbury, ON, P3E 1P2	Regulation:	O.Reg. 243/07
Phone/Fax:	(705) 690-0323 / (705) 671-2442	Project #:	
Email:	polanol@rainbowschools.ca	DWS #:	500039196
		Sampled By:	Jonas French
Date Order Received:	9/11/2019	Analysis Started:	9/16/2019
Arrival Temperature:	18 °C	Analysis Completed:	9/17/2019

WORK ORDER SUMMARY

ANALYSES WERE PERFORMED ON THE FOLLOWING SAMPLES. THE RESULTS RELATE ONLY TO THE ITEMS TESTED.

Sample Description	Lab ID	Matrix	Type	Comments	Date Collected	Time Collected
Standing - Room 4 BS	1474996	Water	Plumbing		9/11/2019	6:30 AM
Flushed - Room 4 BS	1474997	Water	Plumbing		9/11/2019	7:05 AM

METHODS AND INSTRUMENTATION

THE FOLLOWING METHODS WERE USED FOR YOUR SAMPLE(S):

Method	Lab	Description	Reference
ICPMS Reg. Water (A13)	Garson	Determination of Metals in Water by ICP/MS	Modified from SW846-6020A

This report has been approved by:

Brad Halvorson, B.Sc.
Laboratory Director



CERTIFICATE OF ANALYSIS

RDSB - Jean Hansen

Work Order Number: 382509

WORK ORDER RESULTS

Sample Description	Standing - Room 4 BS		Flushed - Room 4 BS			
Sample Date	09/11/2019		09/11/2019			
Lab ID	1474996		1474997			
Metals	Result	MDL	Result	MDL	Units	Criteria: O.Reg. 243/07
Lead	0.5	0.1	0.4	0.1	ug/L	10

LEGEND

Dates: Dates are formatted as mm/dd/year throughout this report.

MDL: Method detection limit or minimum reporting limit.

Quality Control: All associated Quality Control data is available on request.

LCL: Lower Control Limit.

UCL: Upper Control Limit.

QAQCID: This is a unique reference to the quality control data set used to generate the reported value. Contact our lab for this information, as it is traceable through our LIMS.

Exceedences: HIGHLIGHTED CELLS INDICATE THAT THE RESULT EXCEEDS A REGULATORY LIMIT. CALCULATED UNCERTAINTY ESTIMATIONS ARE NOT APPLIED FOR DETERMINING SAMPLE EXCEEDANCES.

Benzo(b)fluoranthene: Results for benzo(b)fluoranthene may include contributions from benzo(j)fluoranthene.

Field Data: Reports containing Field Parameters represent data that has been collected and provided by the client. Testmark is not responsible for the validity of this data which may be used in subsequent calculations.

Sample Condition Deviations: A noted sample condition deviation may affect the validity of the result.



CERTIFICATE OF ANALYSIS

RDSB - Jean Hansen

Work Order Number: 382509

QUALITY CONTROL DATA

THIS SECTION REPORTS QC RESULTS ASSOCIATED WITH THE TEST BATCH; THESE ARE NOT YOUR SAMPLE RESULTS. QAQC details include only values where sufficient sample data allowed measurement.

Metals

Method Blank: LRB-6 (Blank) (6)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	1	ug/L	0	<1	1	20190917.A13.1C

Positive Control: LFB-7 (N 100 µg/L) (7)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	N/A	%	80	92.5	120	20190917.A13.1C

Reference Sample: CRM-12 (EP-L-3) (12)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	1	ug/L	2.64	3.82	5.44	20190917.A13.1C

Sample Spike: LFMS-9 (N 100 µg/L) (9)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	N/A	% Rec	70	93.7	130	20190917.A13.1C

THIS INDEX SHOWS HOW YOUR SAMPLES ARE ASSOCIATED TO THE CONTROLS INCLUDED IN THE IDENTIFIED BATCHES.

Sample Description	Lab ID	Method	QAQCID	Prep QAQCID
Flushed - Room 4 BS	1474997	ICPMS Reg. Water (A13)	20190917.A13.1C	20190916.A520
Standing - Room 4 BS	1474996	ICPMS Reg. Water (A13)	20190917.A13.1C	20190916.A520