



## CERTIFICATE OF ANALYSIS

Client: Lisa Polano  
Company: RDSB - Larchwood Public School  
Address: 69 Young St.  
Sudbury, ON, P3E 3G5  
Phone/Fax: (705) 674-3171 / (705) 761-2442  
Email: polanol@rainbowschools.ca

Work Order Number: 375524  
PO #:   
Regulation: O.Reg. 243/07  
Project #:   
DWS #: 500046086  
Sampled By: Jason Czya

Date Order Received: 6/20/2019  
Arrival Temperature: 12 °C

Analysis Started: 6/23/2019  
Analysis Completed: 6/24/2019

### WORK ORDER SUMMARY

ANALYSES WERE PERFORMED ON THE FOLLOWING SAMPLES. THE RESULTS RELATE ONLY TO THE ITEMS TESTED.

Sample Description	Lab ID	Matrix	Type	Comments	Date Collected	Time Collected
Standing - Daycare 8	1449736	Water	Plumbing		6/20/2019	6:30 AM
Flushed - Daycare 8	1449737	Water	Plumbing		6/20/2019	7:05 AM

### METHODS AND INSTRUMENTATION

THE FOLLOWING METHODS WERE USED FOR YOUR SAMPLE(S):

Method	Lab	Description	Reference
ICPMS Reg. Water (A13)	Garson	Determination of Metals in Water by ICP/MS	Modified from SW846-6020A

This report has been approved by:

Khaled Omari, Ph.D.  
Laboratory Director



## CERTIFICATE OF ANALYSIS

RDSB - Larchwood Public School

Work Order Number: 375524

### WORK ORDER RESULTS

Sample Description	Standing - Daycare 8		Flushed - Daycare 8			
Lab ID	1449736		1449737			
Metals	Result	MDL	Result	MDL	Units	Criteria: O.Reg. 243/07
Lead	8	0.1	1.4	0.1	ug/L	10

### LEGEND

Dates: Dates are formatted as mm/dd/year throughout this report.

MDL: Method detection limit or minimum reporting limit.

Quality Control: All associated Quality Control data is available on request.

Exceedences: HIGHLIGHTED CELLS INDICATE THAT THE RESULT EXCEEDS A REGULATORY LIMIT. CALCULATED UNCERTAINTY ESTIMATIONS ARE NOT APPLIED FOR DETERMINING SAMPLE EXCEEDANCES.

Benzo(b)fluoranthene: Results for benzo(b)fluoranthene may include contributions from benzo(j)fluoranthene.

Field Data: Reports containing Field Parameters represent data that has been collected and provided by the client. Testmark is not responsible for the validity of this data which may be used in subsequent calculations.

Sample Condition Deviations: A noted sample condition deviation may affect the validity of the result.