



**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 500039014

**Project :** PO#017470

15-October-2019

**OCWA-Espanola (Manitoulin Secondary School-Reg243)**

Attn : Keith Stringer

**Date Rec. :** 08 October 2019

**LR Report:** CA15153-OCT19

148 Fleming Street, Suite 5  
Espanola, ON  
P5E 1R8, Canada

**Copy:** #1

Phone: 705-377-4486, or 705-688-5885 or 886-464-0106  
Fax:

# CERTIFICATE OF ANALYSIS


## Final Report

Sample ID	Sample Date & Time	Sampled By	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date			---	11-Oct-19
2: Analysis Start Time			---	13:45
3: Analysis Completed Date			--	15-Oct-19
4: Analysis Completed Time			--	08:55
5: MAC			--	10
6: MDL			---	0.01
7: TAP TAP-Standing 381-B/C	07-Oct-19 07:18	Kevin Woestenenk	16.0	0.67
8: TAP TAP-Flushed 381-B/C	07-Oct-19 07:53	Kevin Woestenenk	16.0	1.07
9: TAP TAP-Standing 381-07	07-Oct-19 07:25	Kevin Woestenenk	16.0	0.01
10: TAP Flushed 381-07	07-Oct-19 08:00	Kevin Woestenenk	16.0	0.16

MAC - Maximum Acceptable Concentration  
MDL - SGS Method Detection Limit

### Method Descriptions

Units	Description	SGS Method Code
ug/L	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006



*Carrie Greenlaw*  
Carrie Greenlaw  
Project Specialist,  
Environment, Health & Safety