



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500039014

Project : PO#017470

15-October-2019

OCWA-Espanola (Manitoulin Secondary School-Reg243)

Attn : Keith Stringer

Date Rec. : 08 October 2019

LR Report: CA15152-OCT19

148 Fleming Street, Suite 5
Espanola, ON
P5E 1R8, Canada

Copy: #1

Phone: 705-377-4486, or 705-688-5885 or 886-464-0106
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Sampled By	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date			---	11-Oct-19
2: Analysis Start Time			---	13:45
3: Analysis Completed Date			--	15-Oct-19
4: Analysis Completed Time			--	08:55
5: MAC			--	10
6: MDL			---	0.01
7: TAP TAP-Standing 381-E	07-Oct-19 07:05	Kevin Woestenenk	16.0	0.14
8: TAP TAP-Flushed 381-E	07-Oct-19 07:40	Kevin Woestenenk	16.0	0.16
9: TAP TAP-Standing 381-H	07-Oct-19 07:27	Kevin Woestenenk	16.0	2.89
10: TAP TAP-Flushed 381-H	07-Oct-19 08:05	Kevin Woestenenk	16.0	1.99

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Method Descriptions

Units	Description	SGS Method Code
ug/L	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Carrie Greenlaw
Project Specialist,
Environment, Health & Safety