



CERTIFICATE OF ANALYSIS

Client: Lisa Polano
Company: RDSB - C.R. Judd Public School
Address: 408 Wembley Drive
Sudbury, ON, P3E 1P2
Phone/Fax: (705) 690-0323 / (705) 671-2442
Email: polanol@rainbowschools.ca

Work Order Number: 387868
PO #:
Regulation: O.Reg. 243/07
Project #:
DWS #: 500040301
Sampled By: Monique Lachance

Date Order Received: 11/11/2019
Arrival Temperature: 3.7 °C

Analysis Started: 11/17/2019
Analysis Completed: 11/18/2019

WORK ORDER SUMMARY

ANALYSES WERE PERFORMED ON THE FOLLOWING SAMPLES. THE RESULTS RELATE ONLY TO THE ITEMS TESTED.

Sample Description	Lab ID	Matrix	Type	Comments	Date Collected	Time Collected
Standing Hall By Gym N/E	1495630	Water	Plumbing		11/11/2019	6:30 AM
Flushed Hall By Gym N/E	1495631	Water	Plumbing		11/11/2019	7:05 AM

METHODS AND INSTRUMENTATION

THE FOLLOWING METHODS WERE USED FOR YOUR SAMPLE(S):

Method	Lab	Description	Reference
ICPMS Reg. Water (A13)	Garson	Determination of Metals in Water by ICP/MS	Modified from SW846-6020A

This report has been approved by:

Brad Halvorson, B.Sc.
Laboratory Director



CERTIFICATE OF ANALYSIS

RDSB - C.R. Judd Public School

Work Order Number: 387868

WORK ORDER RESULTS

Sample Description	Standing Hall By Gym N/E		Flushed Hall By Gym N/E			
Sample Date	11/11/2019 6:30 AM		11/11/2019 7:05 AM			
Lab ID	1495630		1495631			
Metals	Result	MDL	Result	MDL	Units	Criteria: O.Reg. 243/07
Lead	<0.1	0.1	<0.1	0.1	ug/L	10

LEGEND

Dates: Dates are formatted as mm/dd/year throughout this report.

MDL: Method detection limit or minimum reporting limit.

Quality Control: All associated Quality Control data is available on request.

LCL: Lower Control Limit.

UCL: Upper Control Limit.

QAQCID: This is a unique reference to the quality control data set used to generate the reported value. Contact our lab for this information, as it is traceable through our LIMS.

Exceedences: HIGHLIGHTED CELLS INDICATE THAT THE RESULT EXCEEDS A REGULATORY LIMIT. CALCULATED UNCERTAINTY ESTIMATIONS ARE NOT APPLIED FOR DETERMINING SAMPLE EXCEEDANCES.

Benzo(b)fluoranthene: Results for benzo(b)fluoranthene may include contributions from benzo(j)fluoranthene.

Field Data: Reports containing Field Parameters represent data that has been collected and provided by the client. Testmark is not responsible for the validity of this data which may be used in subsequent calculations.

Sample Condition Deviations: A noted sample condition deviation may affect the validity of the result.



CERTIFICATE OF ANALYSIS

RDSB - C.R. Judd Public School

Work Order Number: 387868

QUALITY CONTROL DATA

THIS SECTION REPORTS QC RESULTS ASSOCIATED WITH THE TEST BATCH; THESE ARE NOT YOUR SAMPLE RESULTS. QAQC details include only values where sufficient sample data allowed measurement.

Metals

Method Blank: LRB-6 (Blank) (6)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	1	ug/L	0	<1	1	20191118.A13.1C

Positive Control: LFB-7 (N 100 µg/L) (7)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	N/A	%	80	81.7	120	20191118.A13.1C

Reference Sample: CRM-12 (EP-L-3) (12)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	1	ug/L	2.64	3.42	5.44	20191118.A13.1C

Sample Replicate: % RPD (4)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	N/A	%	0	0.8	20	20191118.A13.1C

Sample Spike: LFMS-9 (N 100 µg/L) (9)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	N/A	% Rec	70	94	130	20191118.A13.1C

THIS INDEX SHOWS HOW YOUR SAMPLES ARE ASSOCIATED TO THE CONTROLS INCLUDED IN THE IDENTIFIED BATCHES.

Sample Description	Lab ID	Method	QAQCID	Prep QAQCID
Flushed Hall By Gym N/E	1495631	ICPMS Reg. Water (A13)	20191118.A13.1C	20191117.A52E
Standing Hall By Gym N/E	1495630	ICPMS Reg. Water (A13)	20191118.A13.1C	20191117.A52E