



CERTIFICATE OF ANALYSIS

Client:	Lisa Polano	Work Order Number:	411046
Company:	RDSB - Chelmsford P.S.	PO #:	
Address:	408 Wembley Drive Sudbury, ON, P3E 1P2	Regulation:	O.Reg. 243/07
Phone/Fax:	(705) 690-0323 / (705) 671-2442	Project #:	
Email:	polanol@rainbowschools.ca	DWS #:	500046073
		Sampled By:	Lisa Polano
Date Order Received:	9/14/2020	Analysis Started:	9/18/2020
Arrival Temperature:	9.1 °C	Analysis Completed:	9/18/2020

WORK ORDER SUMMARY

ANALYSES WERE PERFORMED ON THE FOLLOWING SAMPLES. THE RESULTS RELATE ONLY TO THE ITEMS TESTED.

Sample Description	Lab ID	Matrix	Type	Comments	Date Collected	Time Collected
Standing-Daycare T-3 Rm 2	1575028	Water	Plumbing		9/13/2020	8:00 AM
Flushed-Daycare T-3 Rm 2	1575029	Water	Plumbing		9/13/2020	8:35 AM
Standing-Daycare T-4 Rm 4	1575030	Water	Plumbing		9/13/2020	8:05 AM
Flushed-Daycare T-4 Rm 4	1575031	Water	Plumbing		9/13/2020	8:40 AM

METHODS AND INSTRUMENTATION

THE FOLLOWING METHODS WERE USED FOR YOUR SAMPLE(S):

Method	Lab	Description	Reference
ICPMS Reg. Water (A13)	Garson	Determination of Metals in Water by ICP/MS	Modified from SW846-6020A



TESTMARK Laboratories Ltd.

Committed to Quality and Service

CERTIFICATE OF ANALYSIS

RDSB - Chelmsford P.S.

Work Order Number: 411046

This report has been approved by:

Brad Halvorson, B.Sc.

Laboratory Director



CERTIFICATE OF ANALYSIS

RDSB - Chelmsford P.S.

Work Order Number: 411046

WORK ORDER RESULTS

Sample Description	Standing - Daycare T - 3 Rm 2	Flushed - Daycare T - 3 Rm 2	Standing - Daycare T - 4 Rm 4	Flushed - Daycare T - 4 Rm 4					Units	Criteria: O.Reg. 243/07
Sample Date	9/13/2020 8:00 AM	9/13/2020 8:35 AM	9/13/2020 8:05 AM	9/13/2020 8:40 AM						
Lab ID	1575028	1575029	1575030	1575031						
Metals	Result	MDL	Result	MDL	Result	MDL	Result	MDL		
Lead	1.2	0.1	0.9	0.1	0.4	0.1	1.2	0.1	ug/L	10

LEGEND

Dates: Dates are formatted as mm/dd/year throughout this report.

MDL: Method detection limit or minimum reporting limit.

Quality Control: All associated Quality Control data is available on request.

LCL: Lower Control Limit.

UCL: Upper Control Limit.

QAQCID: This is a unique reference to the quality control data set used to generate the reported value. Contact our lab for this information, as it is traceable through our LIMS.

Field Data: Reports containing Field Parameters represent data that has been collected and provided by the client. Testmark is not responsible for the validity of this data which may be used in subsequent calculations.

Sample Condition Deviations: A noted sample condition deviation may affect the validity of the result. Results apply to the sample(s) as received.



CERTIFICATE OF ANALYSIS

RDSB - Chelmsford P.S.

Work Order Number: 411046

QUALITY CONTROL DATA

THIS SECTION REPORTS QC RESULTS ASSOCIATED WITH THE TEST BATCH; THESE ARE NOT YOUR SAMPLE RESULTS.
QAQC details include only values where sufficient sample data allowed measurement.

Metals

Method Blank: LRB-6 (Blank) (6)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	0.1	ug/L	0	<0.1	1	20200918.A13.1F

Positive Control: LFB-7 (N 100 µg/L) (7)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	N/A	%	80	96.6	120	20200918.A13.1F

Reference Sample: CRM-12 (EP-L-3) (12)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	1	ug/L	2.64	4.04	5.44	20200918.A13.1F

Sample Spike: LFMS-9 (N 100 µg/L) (9)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	N/A	% Rec	70	93.7	130	20200918.A13.1F

THIS INDEX SHOWS HOW YOUR SAMPLES ARE ASSOCIATED TO THE CONTROLS INCLUDED IN THE IDENTIFIED BATCHES.

Sample Description	Lab ID	Method	QAQCID	Prep QAQCID
Flushed - Daycare T - 3 Rm 2	1575029	ICPMS Reg. Water (A13)	20200918.A13.1F	20200917.A52F
Flushed - Daycare T - 4 Rm 4	1575031	ICPMS Reg. Water (A13)	20200918.A13.1F	20200917.A52F
Standing - Daycare T - 3 Rm 2	1575028	ICPMS Reg. Water (A13)	20200918.A13.1F	20200917.A52F
Standing - Daycare T - 4 Rm 4	1575030	ICPMS Reg. Water (A13)	20200918.A13.1F	20200917.A52F