



## CERTIFICATE OF ANALYSIS

Client: Alain Venne  
Company: RDSB - Lansdowne Public School  
Address: 408 Wembley Drive  
Sudbury, ON, P3E 1P2  
Phone/Fax: (705) 919-3531 / (705) 671-2442  
Email: vennea@rainbowschools.ca

Work Order Number: 411514  
PO #:   
Regulation: O.Reg. 243/07  
Project #:   
DWS #: 500045878  
Sampled By: Alain Venne

Date Order Received: 9/17/2020  
Arrival Temperature: 14 °C

Analysis Started: 9/22/2020  
Analysis Completed: 9/24/2020

### WORK ORDER SUMMARY

ANALYSES WERE PERFORMED ON THE FOLLOWING SAMPLES. THE RESULTS RELATE ONLY TO THE ITEMS TESTED.

Sample Description	Lab ID	Matrix	Type	Comments	Date Collected	Time Collected
Standing- S3 room 104	1576735	Treated Water	Plumbing		9/16/2020	6:35 AM
Flushed- S3 room 104	1576736	Treated Water	Plumbing		9/16/2020	7:10 AM
Standing- BF 1 by Room 103	1576737	Treated Water	Plumbing		9/16/2020	6:30 AM
Flushed- BF 1 by Room 103	1576738	Treated Water	Plumbing		9/16/2020	7:05 AM
Standing- BF 3 by Room 003	1576739	Treated Water	Plumbing		9/16/2020	6:30 AM
Flushed- BF 3 by Room 003	1576740	Treated Water	Plumbing		9/17/2020	7:05 AM
Standing- S1 room 106	1576741	Treated Water	Plumbing		9/17/2020	6:35 AM
Flushed- S1 room 106	1576742	Treated Water	Plumbing		9/17/2020	7:10 AM

### METHODS AND INSTRUMENTATION

THE FOLLOWING METHODS WERE USED FOR YOUR SAMPLE(S):

Method	Lab	Description	Reference
ICPMS Reg. Water (A13)	Garson	Determination of Metals in Water by ICP/MS	Modified from SW846-6020A



**TESTMARK Laboratories Ltd.**

*Committed to Quality and Service*

## CERTIFICATE OF ANALYSIS

RDSB - Lansdowne Public School

Work Order Number: 411514

This report has been approved by:

Brad Halvorson, B.Sc.

Laboratory Director



## CERTIFICATE OF ANALYSIS

RDSB - Lansdowne Public School

Work Order Number: 411514

### WORK ORDER RESULTS

Sample Description	Standing - S3 room 104		Flushed - S3 room 104		Standing - BF 1 by Room 103		Flushed - BF 1 by Room 103			
Sample Date	9/16/2020 6:35 AM		9/16/2020 7:10 AM		9/16/2020 6:30 AM		9/16/2020 7:05 AM			
Lab ID	1576735		1576736		1576737		1576738			
Metals	Result	MDL	Result	MDL	Result	MDL	Result	MDL	Units	Criteria: O.Reg. 243/07
Lead	0.5	0.1	0.1	0.1	<0.1	0.1	<0.1	0.1	ug/L	10
Sample Description	Standing - BF 3 by Room 003		Flushed - BF 3 by Room 003		Standing - S1 room 106		Flushed - S1 room 106			
Sample Date	9/16/2020 6:30 AM		9/17/2020 7:05 AM		9/17/2020 6:35 AM		9/17/2020 7:10 AM			
Lab ID	1576739		1576740		1576741		1576742			
Metals	Result	MDL	Result	MDL	Result	MDL	Result	MDL	Units	Criteria: O.Reg. 243/07
Lead	<0.1	0.1	<0.1	0.1	1.9	0.1	0.3	0.1	ug/L	10

### LEGEND

Dates: Dates are formatted as mm/dd/year throughout this report.

MDL: Method detection limit or minimum reporting limit.

Quality Control: All associated Quality Control data is available on request.

Field Data: Reports containing Field Parameters represent data that has been collected and provided by the client. Testmark is not responsible for the validity of this data which may be used in subsequent calculations.

Sample Condition Deviations: A noted sample condition deviation may affect the validity of the result. Results apply to the sample(s) as received.