



CERTIFICATE OF ANALYSIS

Client:	Carol Koziar	Work Order Number:	412999
Company:	RDSB - Lasalle Secondary School	PO #:	
Address:	408 Wembley Drive Sudbury, ON, P3E 1P2	Regulation:	O.Reg. 243/07
Phone/Fax:	(705) 690-0323 / (705) 671-2442	Project #:	
Email:	koziarc@rainbowschools.ca	DWS #:	500045995
		Sampled By:	
Date Order Received:	10/2/2020	Analysis Started:	10/6/2020
Arrival Temperature:	9 °C	Analysis Completed:	10/6/2020

WORK ORDER SUMMARY

ANALYSES WERE PERFORMED ON THE FOLLOWING SAMPLES. THE RESULTS RELATE ONLY TO THE ITEMS TESTED.

Sample Description	Lab ID	Matrix	Type	Comments	Date Collected	Time Collected
STANDING-S 8 SERVERY	1582082	Water	Plumbing		10/2/2020	6:30 AM
FLUSHED-S 8 SERVERY	1582083	Water	Plumbing		10/2/2020	7:05 AM
STANDING-S 4 ROOM 231	1582084	Water	Plumbing		10/2/2020	6:35 AM
FLUSHED-S 4 ROOM 231	1582085	Water	Plumbing		10/2/2020	7:10 AM

METHODS AND INSTRUMENTATION

THE FOLLOWING METHODS WERE USED FOR YOUR SAMPLE(S):

Method	Lab	Description	Reference
ICPMS Reg. Water (A13)	Garson	Determination of Metals in Water by ICP/MS	Modified from SW846-6020A



TESTMARK Laboratories Ltd.

Committed to Quality and Service

CERTIFICATE OF ANALYSIS

RDSB - Lasalle Secondary School

Work Order Number: 412999

This report has been approved by:

Brad Halvorson, B.Sc.
Laboratory Director



CERTIFICATE OF ANALYSIS

RDSB - Lasalle Secondary School

Work Order Number: 412999

WORK ORDER RESULTS

Sample Description	STANDING - S 8 SERVERY		FLUSHED - S 8 SERVERY		STANDING - S 4 ROOM 231		FLUSHED - S 4 ROOM 231			
Sample Date	10/2/2020 6:30 AM		10/2/2020 7:05 AM		10/2/2020 6:35 AM		10/2/2020 7:10 AM			
Lab ID	1582082		1582083		1582084		1582085			
Metals	Result	MDL	Result	MDL	Result	MDL	Result	MDL	Units	Criteria: O.Reg. 243/07
Lead	0.2	0.1	<0.1	0.1	8.0	0.1	0.6	0.1	ug/L	10

LEGEND

Dates: Dates are formatted as mm/dd/year throughout this report.

MDL: Method detection limit or minimum reporting limit.

Quality Control: All associated Quality Control data is available on request.

LCL: Lower Control Limit.

UCL: Upper Control Limit.

QAQCID: This is a unique reference to the quality control data set used to generate the reported value. Contact our lab for this information, as it is traceable through our LIMS.

Field Data: Reports containing Field Parameters represent data that has been collected and provided by the client. Testmark is not responsible for the validity of this data which may be used in subsequent calculations.

Sample Condition Deviations: A noted sample condition deviation may affect the validity of the result. Results apply to the sample(s) as received.



CERTIFICATE OF ANALYSIS

RDSB - Lasalle Secondary School

Work Order Number: 412999

QUALITY CONTROL DATA

THIS SECTION REPORTS QC RESULTS ASSOCIATED WITH THE TEST BATCH; THESE ARE NOT YOUR SAMPLE RESULTS. QAQC details include only values where sufficient sample data allowed measurement.

Metals

Method Blank: LRB-6 (Blank) (6)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	0.1	ug/L	0	<0.1	1	20201006.A13.1K

Positive Control: LFB-7 (N 100 µg/L) (7)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	N/A	%	80	94.7	120	20201006.A13.1K

Reference Sample: CRM-12 (EP-L-3) (12)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	1	ug/L	2.64	4.05	5.44	20201006.A13.1K

Sample Spike: LFMS-9 (N 100 µg/L) (9)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	N/A	% Rec	70	92.7	130	20201006.A13.1K

THIS INDEX SHOWS HOW YOUR SAMPLES ARE ASSOCIATED TO THE CONTROLS INCLUDED IN THE IDENTIFIED BATCHES.

Sample Description	Lab ID	Method	QAQCID	Prep QAQCID
FLUSHED - S 4 ROOM 231	1582085	ICPMS Reg. Water (A13)	20201006.A13.1K	20201004.A52E
FLUSHED - S 8 SERVERY	1582083	ICPMS Reg. Water (A13)	20201006.A13.1K	20201004.A52E
STANDING - S 4 ROOM 231	1582084	ICPMS Reg. Water (A13)	20201006.A13.1K	20201004.A52E
STANDING - S 8 SERVERY	1582082	ICPMS Reg. Water (A13)	20201006.A13.1K	20201004.A52E