



**TESTMARK Laboratories Ltd.**

Committed to Quality and Service

## CERTIFICATE OF ANALYSIS

|                      |   |                     |               |
|----------------------|---|---------------------|---------------|
| Client:              | Carol Koziar                              | Work Order Number:  | 412041        |
| Company:             | RDSB - Westmount Avenue Public School     | PO #:               |               |
| Address:             | 408 Wembley Drive<br>Sudbury, ON, P3E 1P2 | Regulation:         | O.Reg. 243/07 |
| Phone/Fax:           | (705) 690-0323 / (705) 671-2442           | Project #:          |               |
| Email:               | koziarc@rainbowschools.ca                 | DWS #:              | 500040288     |
|                      |   | Sampled By:         | Carol Koziar  |
| Date Order Received: | 9/23/2020                                 | Analysis Started:   | 9/28/2020     |
| Arrival Temperature: | 9 °C                                      | Analysis Completed: | 9/28/2020     |

### WORK ORDER SUMMARY

ANALYSES WERE PERFORMED ON THE FOLLOWING SAMPLES. THE RESULTS RELATE ONLY TO THE ITEMS TESTED.

| Sample Description        | Lab ID  | Matrix | Type     | Comments | Date Collected | Time Collected |
|---------------------------|---------|--------|----------|----------|----------------|----------------|
| Standing - BF 1 by room 4 | 1578621 | Water  | Plumbing |          | 9/22/2020      | 7:00 AM        |
| Flushed - BF 1 by room 4  | 1578622 | Water  | Plumbing |          | 9/22/2020      | 7:35 AM        |
| Standing - S 1 Room 4     | 1578623 | Water  | Plumbing |          | 9/22/2020      | 7:05 AM        |
| Flushed - S 1 Room 4      | 1578624 | Water  | Plumbing |          | 9/22/2020      | 7:40 AM        |
| Standing - S 2 Staff Room | 1578625 | Water  | Plumbing |          | 9/22/2020      | 7:10 AM        |
| Flushed - S 2 Staff Room  | 1578626 | Water  | Plumbing |          | 9/22/2020      | 7:45 AM        |

### METHODS AND INSTRUMENTATION

THE FOLLOWING METHODS WERE USED FOR YOUR SAMPLE(S):

| Method                 | Lab    | Description                                | Reference                 |
|------------------------|--------|--|---------------------------|
| ICPMS Reg. Water (A13) | Garson | Determination of Metals in Water by ICP/MS | Modified from SW846-6020A |



**TESTMARK Laboratories Ltd.**

*Committed to Quality and Service*

## CERTIFICATE OF ANALYSIS

RDSB - Westmount Avenue Public School

Work Order Number: 412041

This report has been approved by:

Brad Halvorson, B.Sc.

Laboratory Director



## CERTIFICATE OF ANALYSIS

RDSB - Westmount Avenue Public School

Work Order Number: 412041

### WORK ORDER RESULTS

| Sample Description | Standing - BF 1 by room 4 |     | Flushed - BF 1 by room 4 |     | Standing - S 1 Room 4 |     | Flushed - S 1 Room 4 |     |       |                         |
|--------------------|---------------------------|-----|--------------------------|-----|-----------------------|-----|----------------------|-----|-------|-------------------------|
| Sample Date        | 9/22/2020 7:00 AM         |     | 9/22/2020 7:35 AM        |     | 9/22/2020 7:05 AM     |     | 9/22/2020 7:40 AM    |     |       |                         |
| Lab ID             | 1578621                   |     | 1578622                  |     | 1578623               |     | 1578624              |     |       |                         |
| Metals             | Result                    | MDL | Result                   | MDL | Result                | MDL | Result               | MDL | Units | Criteria: O.Reg. 243/07 |
| Lead               | <0.1                      | 0.1 | <0.1                     | 0.1 | 0.1                   | 0.1 | <0.1                 | 0.1 | ug/L  | 10                      |

  

| Sample Description | Standing - S 2 Staff Room |     | Flushed - S 2 Staff Room |     |       |                         |
|--------------------|---------------------------|-----|--------------------------|-----|-------|-------------------------|
| Sample Date        | 9/22/2020 7:10 AM         |     | 9/22/2020 7:45 AM        |     |       |                         |
| Lab ID             | 1578625                   |     | 1578626                  |     |       |                         |
| Metals             | Result                    | MDL | Result                   | MDL | Units | Criteria: O.Reg. 243/07 |
| Lead               | 6.1<br>[6.2]              | 0.1 | 0.4                      | 0.1 | ug/L  | 10                      |

### LEGEND

Dates: Dates are formatted as mm/dd/year throughout this report.

MDL: Method detection limit or minimum reporting limit.

[ ]: Results for laboratory replicates are shown in square brackets immediately below the associated sample result for ease of comparison.

Quality Control: All associated Quality Control data is available on request.

LCL: Lower Control Limit.

UCL: Upper Control Limit.

QAQCID: This is a unique reference to the quality control data set used to generate the reported value. Contact our lab for this information, as it is traceable through our LIMS.

Field Data: Reports containing Field Parameters represent data that has been collected and provided by the client. Testmark is not responsible for the validity of this data which may be used in subsequent calculations.

Sample Condition Deviations: A noted sample condition deviation may affect the validity of the result. Results apply to the sample(s) as received.



## CERTIFICATE OF ANALYSIS

RDSB - Westmount Avenue Public School

Work Order Number: 412041

### QUALITY CONTROL DATA

THIS SECTION REPORTS QC RESULTS ASSOCIATED WITH THE TEST BATCH; THESE ARE NOT YOUR SAMPLE RESULTS.  
QAQC details include only values where sufficient sample data allowed measurement.

#### Metals

##### Method Blank: LRB-6 (Blank) (6)

| Parameter | MDL | Units | LCL | Result | UCL | QAQCID          |
|-----------|-----|-------|-----|--------|-----|-----------------|
| Lead      | 0.1 | ug/L  | 0   | <0.1   | 1   | 20200928.A13.1B |
| Lead      | 0.1 | ug/L  | 0   | <0.1   | 1   | 20200928.A13.1D |

##### Positive Control: LFB-7 (N 100 µg/L) (7)

| Parameter | MDL | Units | LCL | Result | UCL | QAQCID          |
|-----------|-----|-------|-----|--------|-----|-----------------|
| Lead      | N/A | %     | 80  | 94.2   | 120 | 20200928.A13.1B |
| Lead      | N/A | %     | 80  | 96.4   | 120 | 20200928.A13.1D |

##### Reference Sample: CRM-12 (EP-L-3) (12)

| Parameter | MDL | Units | LCL  | Result | UCL  | QAQCID          |
|-----------|-----|-------|------|--------|------|-----------------|
| Lead      | 1   | ug/L  | 2.64 | 4.15   | 5.44 | 20200928.A13.1B |
| Lead      | 1   | ug/L  | 2.64 | 4.17   | 5.44 | 20200928.A13.1D |

##### Sample Replicate: % RPD (4)

| Parameter | MDL | Units | LCL | Result | UCL | QAQCID          |
|-----------|-----|-------|-----|--------|-----|-----------------|
| Lead      | N/A | %     | 0   | 1.6    | 20  | 20200928.A13.1B |

##### Sample Spike: LFMS-9 (N 100 µg/L) (9)

| Parameter | MDL | Units | LCL | Result | UCL | QAQCID          |
|-----------|-----|-------|-----|--------|-----|-----------------|
| Lead      | N/A | % Rec | 70  | 100    | 130 | 20200928.A13.1D |
| Lead      | N/A | % Rec | 70  | 101    | 130 | 20200928.A13.1B |



## CERTIFICATE OF ANALYSIS

RDSB - Westmount Avenue Public School

Work Order Number: 412041

THIS INDEX SHOWS HOW YOUR SAMPLES ARE ASSOCIATED TO THE CONTROLS INCLUDED IN THE IDENTIFIED BATCHES.

| Sample Description        | Lab ID   | Method                 | QAQCID          | Prep QAQCID   |
|---------------------------|----------|------------------------|-----------------|---------------|
| Flushed - BF 1 by room 4  | 1578622  | ICPMS Reg. Water (A13) | 20200928.A13.1D | 20200927.A52C |
| Flushed - S 1 Room 4      | 1578624  | ICPMS Reg. Water (A13) | 20200928.A13.1D | 20200927.A52C |
| Flushed - S 2 Staff Room  | 1578626  | ICPMS Reg. Water (A13) | 20200928.A13.1B | 20200927.A52D |
| Standing - BF 1 by room 4 | 1578621  | ICPMS Reg. Water (A13) | 20200928.A13.1D | 20200927.A52C |
| Standing - S 1 Room 4     | 1578623  | ICPMS Reg. Water (A13) | 20200928.A13.1D | 20200927.A52C |
| Standing - S 2 Staff Room | 1578625  | ICPMS Reg. Water (A13) | 20200928.A13.1B | 20200927.A52D |
| Standing - S 2 Staff Room | 1578625r | ICPMS Reg. Water (A13) | 20200928.A13.1B | 20200927.A52D |