



CERTIFICATE OF ANALYSIS

| | | | |
|----------------------|---|---------------------|-----------------|
| Client: | Steve McCulloch | Work Order Number: | 442225 |
| Company: | RDSB - Espanola H.S. - AB ELLIS PS | PO #: | |
| Address: | 408 Wembley Drive Sudbury, ON, P3E 1P2 | Regulation: | O.Reg. 243/07 |
| Phone/Fax: | (705) 674-3171 / (705) 671-2442 | Project #: | |
| Email: | mcculls@rainbowschools.ca | DWS #: | 500039053 |
| | | Sampled By: | Steve McCulloch |
| Date Order Received: | 9/13/2021 | Analysis Started: | 9/20/2021 |
| Arrival Temperature: | 6 °C | Analysis Completed: | 9/21/2021 |

WORK ORDER SUMMARY

ANALYSES WERE PERFORMED ON THE FOLLOWING SAMPLES. THE RESULTS RELATE ONLY TO THE ITEMS TESTED.

| Sample Description | Lab ID | Matrix | Type | Comments | Date Collected | Time Collected |
|--------------------|---------|--------|----------|----------|----------------|----------------|
| Standing-S-78A | 1682412 | Water | Plumbing | | 9/11/2021 | 4:00 PM |
| Flushed-S-78A | 1682413 | Water | Plumbing | | 9/11/2021 | 4:35 PM |
| Standing-S-75 | 1682414 | Water | Plumbing | | 9/11/2021 | 4:05 PM |
| Flushed-S-75 | 1682415 | Water | Plumbing | | 9/11/2021 | 4:40 PM |
| Standing-FB131B | 1682416 | Water | Plumbing | | 9/11/2021 | 4:10 PM |
| Flushed-FB131B | 1682417 | Water | Plumbing | | 9/11/2021 | 4:45 PM |
| Standing-FB228 | 1682418 | Water | Plumbing | | 9/11/2021 | 4:15 PM |
| Flushed-FB228 | 1682419 | Water | Plumbing | | 9/11/2021 | 4:50 PM |
| Standing-SE69B | 1682420 | Water | Plumbing | | 9/11/2021 | 4:20 PM |
| Flushed-SE69B | 1682421 | Water | Plumbing | | 9/11/2021 | 4:55 PM |
| Standing-F1 | 1682422 | Water | Plumbing | | 9/11/2021 | 4:25 PM |
| Flushed-F1 | 1682423 | Water | Plumbing | | 9/11/2021 | 5:00 PM |
| Standing-F4 | 1682424 | Water | Plumbing | | 9/11/2021 | 4:20 PM |
| Flushed-F4 | 1682425 | Water | Plumbing | | 9/11/2021 | 5:05 PM |
| Standing-FB6 | 1682426 | Water | Plumbing | | 9/11/2021 | 4:35 PM |
| Flushed-FB-6 | 1682427 | Water | Plumbing | | 9/11/2021 | 5:10 PM |
| Standing-F7 | 1682428 | Water | Plumbing | | 9/11/2021 | 4:40 PM |



CERTIFICATE OF ANALYSIS

RDSB - Espanola H.S. - AB ELLIS PS

Work Order Number: 442225

| Sample Description | Lab ID | Matrix | Type | Comments | Date Collected | Time Collected |
|--------------------|---------|--------|----------|----------|----------------|----------------|
| Flushed-F7 | 1682429 | Water | Plumbing | | 9/11/2021 | 5:15 PM |
| Standing-SC119B | 1682430 | Water | Plumbing | | 9/11/2021 | 4:45 PM |
| Flushed-SC119B | 1682431 | Water | Plumbing | | 9/11/2021 | 5:20 PM |
| Standing-SC119E | 1682432 | Water | Plumbing | | 9/11/2021 | 4:50 PM |
| Flushed-SC119E | 1682433 | Water | Plumbing | | 9/11/2021 | 5:25 PM |
| Standing-SC119G | 1682434 | Water | Plumbing | | 9/11/2021 | 4:55 PM |
| Flushed-SC119G | 1682435 | Water | Plumbing | | 9/11/2021 | 5:30 PM |
| Standing-S97A | 1682436 | Water | Plumbing | | 9/11/2021 | 5:00 PM |
| Flushed-S97A | 1682437 | Water | Plumbing | | 9/11/2021 | 5:35 PM |

METHODS AND INSTRUMENTATION

THE FOLLOWING METHODS WERE USED FOR YOUR SAMPLE(S):

| Method | Lab | Description | Reference |
|------------------------|--------|--|---------------------------|
| ICPMS Reg. Water (A13) | Garson | Determination of Metals in Water by ICP/MS | Modified from SW846-6020A |

This report has been approved by:

Mahesh Patel, B.Sc.
Laboratory Director



CERTIFICATE OF ANALYSIS

RDSB - Espanola H.S. - AB ELLIS PS

Work Order Number: 442225

WORK ORDER RESULTS

| Sample Description | Standing - S - 78A | | Flushed - S - 78A | | Standing - S - 75 | | Flushed - S - 75 | | | |
|--------------------|--------------------|-----|-------------------|-----|-------------------|-----|-------------------|-----|-------|-------------------------|
| Sample Date | 9/11/2021 4:00 PM | | 9/11/2021 4:35 PM | | 9/11/2021 4:05 PM | | 9/11/2021 4:40 PM | | | |
| Lab ID | 1682412 | | 1682413 | | 1682414 | | 1682415 | | | |
| Metals | Result | MDL | Result | MDL | Result | MDL | Result | MDL | Units | Criteria: O.Reg. 243/07 |
| Lead | <0.1 | 0.1 | <0.1 | 0.1 | <0.1 | 0.1 | <0.1 | 0.1 | ug/L | 10 |
| Sample Description | Standing - FB131B | | Flushed - FB131B | | Standing - FB228 | | Flushed - FB228 | | | |
| Sample Date | 9/11/2021 4:10 PM | | 9/11/2021 4:45 PM | | 9/11/2021 4:15 PM | | 9/11/2021 4:50 PM | | | |
| Lab ID | 1682416 | | 1682417 | | 1682418 | | 1682419 | | | |
| Metals | Result | MDL | Result | MDL | Result | MDL | Result | MDL | Units | Criteria: O.Reg. 243/07 |
| Lead | 0.5 | 0.1 | 0.2 | 0.1 | 0.1 | 0.1 | <0.1 | 0.1 | ug/L | 10 |
| Sample Description | Standing - SE69B | | Flushed - SE69B | | Standing - F1 | | Flushed - F1 | | | |
| Sample Date | 9/11/2021 4:20 PM | | 9/11/2021 4:55 PM | | 9/11/2021 4:25 PM | | 9/11/2021 5:00 PM | | | |
| Lab ID | 1682420 | | 1682421 | | 1682422 | | 1682423 | | | |
| Metals | Result | MDL | Result | MDL | Result | MDL | Result | MDL | Units | Criteria: O.Reg. 243/07 |
| Lead | <0.1 | 0.1 | <0.1 | 0.1 | 0.2 | 0.1 | <0.1 | 0.1 | ug/L | 10 |
| Sample Description | Standing - F4 | | Flushed - F4 | | Standing - FB6 | | Flushed - FB - 6 | | | |
| Sample Date | 9/11/2021 4:20 PM | | 9/11/2021 5:05 PM | | 9/11/2021 4:35 PM | | 9/11/2021 5:10 PM | | | |
| Lab ID | 1682424 | | 1682425 | | 1682426 | | 1682427 | | | |
| Metals | Result | MDL | Result | MDL | Result | MDL | Result | MDL | Units | Criteria: O.Reg. 243/07 |
| Lead | 0.3 | 0.1 | 0.6 | 0.1 | 0.2 | 0.1 | 0.2 | 0.1 | ug/L | 10 |



CERTIFICATE OF ANALYSIS

RDSB - Espanola H.S. - AB ELLIS PS

Work Order Number: 442225

| Sample Description | Standing - F7 | | Flushed - F7 | | Standing - SC119B | | Flushed - SC119B | | | |
|--------------------|-------------------|-----|-------------------|-----|-------------------|-------------------------|-------------------|-----|-------|-------------------------|
| Sample Date | 9/11/2021 4:40 PM | | 9/11/2021 5:15 PM | | 9/11/2021 4:45 PM | | 9/11/2021 5:20 PM | | | |
| Lab ID | 1682428 | | 1682429 | | 1682430 | | 1682431 | | | |
| Metals | Result | MDL | Result | MDL | Result | MDL | Result | MDL | Units | Criteria: O.Reg. 243/07 |
| Lead | 0.3 | 0.1 | 0.2 | 0.1 | <0.1 | 0.1 | <0.1 | 0.1 | ug/L | 10 |
| Sample Description | Standing - SC119E | | Flushed - SC119E | | Standing - SC119G | | Flushed - SC119G | | | |
| Sample Date | 9/11/2021 4:50 PM | | 9/11/2021 5:25 PM | | 9/11/2021 4:55 PM | | 9/11/2021 5:30 PM | | | |
| Lab ID | 1682432 | | 1682433 | | 1682434 | | 1682435 | | | |
| Metals | Result | MDL | Result | MDL | Result | MDL | Result | MDL | Units | Criteria: O.Reg. 243/07 |
| Lead | 0.1 | 0.1 | <0.1 | 0.1 | 0.9 | 0.1 | <0.1 | 0.1 | ug/L | 10 |
| Sample Description | Standing - S97A | | Flushed - S97A | | | | | | | |
| Sample Date | 9/11/2021 5:00 PM | | 9/11/2021 5:35 PM | | | | | | | |
| Lab ID | 1682436 | | 1682437 | | | | | | | |
| Metals | Result | MDL | Result | MDL | Units | Criteria: O.Reg. 243/07 | | | | |
| Lead | 0.3 | 0.1 | 0.2 [0.2] | 0.1 | ug/L | 10 | | | | |



TESTMARK Laboratories Ltd.

Committed to Quality and Service

CERTIFICATE OF ANALYSIS

RDSB - Espanola H.S. - AB ELLIS PS

Work Order Number: 442225

LEGEND

Dates: Dates are formatted as mm/dd/year throughout this report.

MDL: Method detection limit or minimum reporting limit.

[]: Results for laboratory replicates are shown in square brackets immediately below the associated sample result for ease of comparison.

Quality Control: All associated Quality Control data is available on request.

LCL: Lower Control Limit.

UCL: Upper Control Limit.

QAQCID: This is a unique reference to the quality control data set used to generate the reported value. Contact our lab for this information, as it is traceable through our LIMS.

Field Data: Reports containing Field Parameters represent data that has been collected and provided by the client. Testmark is not responsible for the validity of this data which may be used in subsequent calculations.

Sample Condition Deviations: A noted sample condition deviation may affect the validity of the result. Results apply to the sample(s) as received.

Reproduction of Report: Report shall not be reproduced, except in full, without the approval of Testmark Laboratories Ltd.



CERTIFICATE OF ANALYSIS

RDSB - Espanola H.S. - AB ELLIS PS

Work Order Number: 442225

QUALITY CONTROL DATA

THIS SECTION REPORTS QC RESULTS ASSOCIATED WITH THE TEST BATCH; THESE ARE NOT YOUR SAMPLE RESULTS.
QAQC details include only values where sufficient sample data allowed measurement.

Metals

Method Blank: LRB-6 (Blank) (6)

| Parameter | MDL | Units | LCL | Result | UCL | QAQCID |
|-----------|-----|-------|-----|--------|-----|-----------------|
| Lead | 0.1 | ug/L | 0 | <0.1 | 1 | 20210920.A13.1B |
| Lead | 0.1 | ug/L | 0 | <0.1 | 1 | 20210920.A13.1F |
| Lead | 0.1 | ug/L | 0 | <0.1 | 1 | 20210921.A13.1D |
| Lead | 0.1 | ug/L | 0 | <0.1 | 1 | 20210921.A13.1E |
| Lead | 0.1 | ug/L | 0 | <0.1 | 1 | 20210921.A13.1F |

Positive Control: LFB-7 (N 100 µg/L) (7)

| Parameter | MDL | Units | LCL | Result | UCL | QAQCID |
|-----------|-----|-------|-----|--------|-----|-----------------|
| Lead | N/A | % | 80 | 95.4 | 120 | 20210921.A13.1D |
| Lead | N/A | % | 80 | 95.6 | 120 | 20210920.A13.1B |
| Lead | N/A | % | 80 | 95.9 | 120 | 20210921.A13.1F |
| Lead | N/A | % | 80 | 96.3 | 120 | 20210920.A13.1F |
| Lead | N/A | % | 80 | 96.6 | 120 | 20210921.A13.1E |

Reference Sample: CRM-12 (EP-L-3) (12)

| Parameter | MDL | Units | LCL | Result | UCL | QAQCID |
|-----------|-----|-------|------|--------|------|-----------------|
| Lead | 1 | ug/L | 2.58 | 4.02 | 5.38 | 20210921.A13.1F |
| Lead | 1 | ug/L | 2.58 | 4.06 | 5.38 | 20210920.A13.1F |
| Lead | 1 | ug/L | 2.58 | 4.06 | 5.38 | 20210921.A13.1D |
| Lead | 1 | ug/L | 2.58 | 4.08 | 5.38 | 20210920.A13.1B |
| Lead | 1 | ug/L | 2.58 | 4.11 | 5.38 | 20210921.A13.1E |

Sample Replicate: % RPD (4)

| Parameter | MDL | Units | LCL | Result | UCL | QAQCID |
|-----------|-----|-------|-----|--------|-----|-----------------|
| Lead | N/A | % | 0 | 2.6 | 20 | 20210921.A13.1F |



TESTMARK Laboratories Ltd.

Committed to Quality and Service

CERTIFICATE OF ANALYSIS

RDSB - Espanola H.S. - AB ELLIS PS

Work Order Number: 442225

Sample Spike: LFMS-9 (N 100 µg/L) (9)

| Parameter | MDL | Units | LCL | Result | UCL | QAQCID |
|-----------|-----|-------|-----|--------|-----|-----------------|
| Lead | N/A | % Rec | 70 | 89.7 | 130 | 20210920.A13.1F |
| Lead | N/A | % Rec | 70 | 92 | 130 | 20210921.A13.1E |
| Lead | N/A | % Rec | 70 | 92.9 | 130 | 20210921.A13.1D |
| Lead | N/A | % Rec | 70 | 94.9 | 130 | 20210920.A13.1B |
| Lead | N/A | % Rec | 70 | 97.5 | 130 | 20210921.A13.1F |



CERTIFICATE OF ANALYSIS

RDSB - Espanola H.S. - AB ELLIS PS

Work Order Number: 442225

THIS INDEX SHOWS HOW YOUR SAMPLES ARE ASSOCIATED TO THE CONTROLS INCLUDED IN THE IDENTIFIED BATCHES.

| Sample Description | Lab ID | Method | QAQCID | Prep QAQCID |
|--------------------|----------|------------------------|-----------------|---------------|
| Flushed - F1 | 1682423 | ICPMS Reg. Water (A13) | 20210921.A13.1E | 20210917.A52Q |
| Flushed - F4 | 1682425 | ICPMS Reg. Water (A13) | 20210921.A13.1E | 20210917.A52Q |
| Flushed - F7 | 1682429 | ICPMS Reg. Water (A13) | 20210920.A13.1B | 20210915.A52Y |
| Flushed - FB - 6 | 1682427 | ICPMS Reg. Water (A13) | 20210920.A13.1F | 20210915.A52X |
| Flushed - FB131B | 1682417 | ICPMS Reg. Water (A13) | 20210920.A13.1F | 20210915.A52X |
| Flushed - FB228 | 1682419 | ICPMS Reg. Water (A13) | 20210920.A13.1B | 20210915.A52Y |
| Flushed - S - 75 | 1682415 | ICPMS Reg. Water (A13) | 20210921.A13.1E | 20210917.A52Q |
| Flushed - S - 78A | 1682413 | ICPMS Reg. Water (A13) | 20210921.A13.1E | 20210917.A52Q |
| Flushed - S97A | 1682437 | ICPMS Reg. Water (A13) | 20210920.A13.1F | 20210915.A52X |
| Flushed - S97A | 1682437r | ICPMS Reg. Water (A13) | 20210920.A13.1F | 20210915.A52X |
| Flushed - SC119B | 1682431 | ICPMS Reg. Water (A13) | 20210921.A13.1D | 20210917.A52P |
| Flushed - SC119E | 1682433 | ICPMS Reg. Water (A13) | 20210921.A13.1D | 20210917.A52P |
| Flushed - SC119G | 1682435 | ICPMS Reg. Water (A13) | 20210921.A13.1F | 20210917.A52T |
| Flushed - SE69B | 1682421 | ICPMS Reg. Water (A13) | 20210921.A13.1D | 20210917.A52P |
| Standing - F1 | 1682422 | ICPMS Reg. Water (A13) | 20210921.A13.1D | 20210917.A52P |
| Standing - F4 | 1682424 | ICPMS Reg. Water (A13) | 20210921.A13.1E | 20210917.A52Q |
| Standing - F7 | 1682428 | ICPMS Reg. Water (A13) | 20210920.A13.1B | 20210915.A52Y |
| Standing - FB131B | 1682416 | ICPMS Reg. Water (A13) | 20210920.A13.1F | 20210915.A52X |
| Standing - FB228 | 1682418 | ICPMS Reg. Water (A13) | 20210920.A13.1B | 20210915.A52Y |
| Standing - FB6 | 1682426 | ICPMS Reg. Water (A13) | 20210920.A13.1F | 20210915.A52X |
| Standing - S - 75 | 1682414 | ICPMS Reg. Water (A13) | 20210921.A13.1E | 20210917.A52Q |
| Standing - S - 78A | 1682412 | ICPMS Reg. Water (A13) | 20210921.A13.1D | 20210917.A52P |
| Standing - S97A | 1682436 | ICPMS Reg. Water (A13) | 20210920.A13.1B | 20210915.A52Y |
| Standing - SC119B | 1682430 | ICPMS Reg. Water (A13) | 20210921.A13.1D | 20210917.A52P |
| Standing - SC119E | 1682432 | ICPMS Reg. Water (A13) | 20210921.A13.1D | 20210917.A52P |
| Standing - SC119G | 1682434 | ICPMS Reg. Water (A13) | 20210921.A13.1F | 20210917.A52T |
| Standing - SE69B | 1682420 | ICPMS Reg. Water (A13) | 20210921.A13.1D | 20210917.A52P |