



TESTMARK Laboratories Ltd.

Committed to Quality and Service

CERTIFICATE OF ANALYSIS

Client: Alain Venne
Company: RDSB - Copper Cliff Public School
Address: 408 Wembley Drive
Sudbury, ON, P3E 1P2
Phone/Fax: (705) 919-3531 / (705) 671-2442
Email: vennea@rainbowschools.ca

Work Order Number: 442601
PO #:
Regulation: O.Reg. 243/07
Project #:
DWS #: 500045852
Sampled By: Illegible

Date Order Received: 9/15/2021
Arrival Temperature: 11.5 °C

Analysis Started: 9/24/2021
Analysis Completed: 9/24/2021

WORK ORDER SUMMARY

ANALYSES WERE PERFORMED ON THE FOLLOWING SAMPLES. THE RESULTS RELATE ONLY TO THE ITEMS TESTED.

Sample Description	Lab ID	Matrix	Type	Comments	Date Collected	Time Collected
Standing-S1 room 102	1683848	Water	Plumbing		9/15/2021	6:35 AM
Flushed-S1 room 102	1683849	Water	Plumbing		9/15/2021	7:10 AM
Standing-S6 room 216	1683850	Water	Plumbing		9/15/2021	6:30 AM
Standing-S6 room 216	1683851	Water	Plumbing		9/15/2021	7:05 AM

METHODS AND INSTRUMENTATION

THE FOLLOWING METHODS WERE USED FOR YOUR SAMPLE(S):

Method	Lab	Description	Reference
ICPMS Reg. Water (A13)	Garson	Determination of Metals in Water by ICP/MS	Modified from SW846-6020A



TESTMARK Laboratories Ltd.

Committed to Quality and Service

CERTIFICATE OF ANALYSIS

RDSB - Copper Cliff Public School

Work Order Number: 442601

This report has been approved by:

Mahesh Patel, B.Sc.
Laboratory Director



CERTIFICATE OF ANALYSIS

RDSB - Copper Cliff Public School

Work Order Number: 442601

WORK ORDER RESULTS

Sample Description	Standing - S1 room 102		Flushed - S1 room 102		Standing - S6 room 216		Standing - S6 room 216			
Sample Date	9/15/2021 6:35 AM		9/15/2021 7:10 AM		9/15/2021 6:30 AM		9/15/2021 7:05 AM			
Lab ID	1683848		1683849		1683850		1683851			
Metals	Result	MDL	Result	MDL	Result	MDL	Result	MDL	Units	Criteria: O.Reg. 243/07
Lead	<0.1	0.1	<0.1	0.1	<0.1	0.1	<0.1	0.1	ug/L	10

LEGEND

Dates: Dates are formatted as mm/dd/year throughout this report.

MDL: Method detection limit or minimum reporting limit.

Quality Control: All associated Quality Control data is available on request.

LCL: Lower Control Limit.

UCL: Upper Control Limit.

QAQCID: This is a unique reference to the quality control data set used to generate the reported value. Contact our lab for this information, as it is traceable through our LIMS.

Field Data: Reports containing Field Parameters represent data that has been collected and provided by the client. Testmark is not responsible for the validity of this data which may be used in subsequent calculations.

Sample Condition Deviations: A noted sample condition deviation may affect the validity of the result. Results apply to the sample(s) as received.

Reproduction of Report: Report shall not be reproduced, except in full, without the approval of Testmark Laboratories Ltd.



CERTIFICATE OF ANALYSIS

RDSB - Copper Cliff Public School

Work Order Number: 442601

QUALITY CONTROL DATA

THIS SECTION REPORTS QC RESULTS ASSOCIATED WITH THE TEST BATCH; THESE ARE NOT YOUR SAMPLE RESULTS.
QAQC details include only values where sufficient sample data allowed measurement.

Metals

Method Blank: LRB-6 (Blank) (6)							
Parameter	MDL	Units	LCL	Result	UCL	QAQCID	
Lead	0.1	ug/L	0	<0.1	1	20210924.A13.1C	
Lead	0.1	ug/L	0	<0.1	1	20210924.A13.1E	
Positive Control: LFB-7 (N 100 µg/L) (7)							
Parameter	MDL	Units	LCL	Result	UCL	QAQCID	
Lead	N/A	%	80	95.2	120	20210924.A13.1E	
Lead	N/A	%	80	96.6	120	20210924.A13.1C	
Reference Sample: CRM-12 (EP-L-3) (12)							
Parameter	MDL	Units	LCL	Result	UCL	QAQCID	
Lead	1	ug/L	2.58	3.89	5.38	20210924.A13.1C	
Lead	1	ug/L	2.58	3.99	5.38	20210924.A13.1E	
Sample Spike: LFMS-9 (N 100 µg/L) (9)							
Parameter	MDL	Units	LCL	Result	UCL	QAQCID	
Lead	N/A	% Rec	70	91.5	130	20210924.A13.1E	
Lead	N/A	% Rec	70	91.9	130	20210924.A13.1C	

THIS INDEX SHOWS HOW YOUR SAMPLES ARE ASSOCIATED TO THE CONTROLS INCLUDED IN THE IDENTIFIED BATCHES.

Sample Description	Lab ID	Method	QAQCID	Prep QAQCID
Flushed - S1 room 102	1683849	ICPMS Reg. Water (A13)	20210924.A13.1E	20210923.A52N
Standing - S1 room 102	1683848	ICPMS Reg. Water (A13)	20210924.A13.1E	20210923.A52N
Standing - S6 room 216	1683850	ICPMS Reg. Water (A13)	20210924.A13.1C	20210922.A52U
Standing - S6 room 216	1683851	ICPMS Reg. Water (A13)	20210924.A13.1C	20210922.A52U