



CERTIFICATE OF ANALYSIS

Client:	Carol Koziar	Work Order Number:	445514
Company:	RDSB - Churchill Public School	PO #:	
Address:	408 Wembley Drive Sudbury, ON, P3E 1P2	Regulation:	O.Reg. 243/07
Phone/Fax:	(705) 690-0323 / (705) 671-2442	Project #:	
Email:	koziarc@rainbowschools.ca	DWS #:	500046047
		Sampled By:	Carol Koziar
Date Order Received:	10/14/2021	Analysis Started:	10/18/2021
Arrival Temperature:	9.3 °C	Analysis Completed:	10/18/2021

WORK ORDER SUMMARY

ANALYSES WERE PERFORMED ON THE FOLLOWING SAMPLES. THE RESULTS RELATE ONLY TO THE ITEMS TESTED.

Sample Description	Lab ID	Matrix	Type	Comments	Date Collected	Time Collected
Standing-S-4 Room 17 A	1694858	Water	Plumbing		10/13/2021	6:30 AM
Flushed-S-4 Room 17 A	1694859	Water	Plumbing		10/13/2021	7:05 AM
Standing-S-6 Room 4 Daycare	1694860	Water	Plumbing		10/13/2021	6:35 AM
Flushed-S-6 Room 4 Daycare	1694861	Water	Plumbing		10/13/2021	7:10 AM

METHODS AND INSTRUMENTATION

THE FOLLOWING METHODS WERE USED FOR YOUR SAMPLE(S):

Method	Lab	Description	Reference
ICPMS Reg. Water (A13)	Garson	Determination of Metals in Water by ICP/MS	Modified from SW846-6020A



TESTMARK Laboratories Ltd.

Committed to Quality and Service

CERTIFICATE OF ANALYSIS

RDSB - Churchill Public School

Work Order Number: 445514

This report has been approved by:

Mahesh Patel, B.Sc.
Laboratory Director



CERTIFICATE OF ANALYSIS

RDSB - Churchill Public School

Work Order Number: 445514

WORK ORDER RESULTS

Sample Description	Standing - S - 4 Room 17 A		Flushed - S - 4 Room 17 A		Standing - S - 6 Room 4 Daycare		Flushed - S - 6 Room 4 Daycare			
Sample Date	10/13/2021 6:30 AM		10/13/2021 7:05 AM		10/13/2021 6:35 AM		10/13/2021 7:10 AM			
Lab ID	1694858		1694859		1694860		1694861			
Metals	Result	MDL	Result	MDL	Result	MDL	Result	MDL	Units	Criteria: O.Reg. 243/07
Lead	<0.1	0.1	<0.1	0.1	<0.1	0.1	<0.1	0.1	ug/L	10

LEGEND

Dates: Dates are formatted as mm/dd/year throughout this report.

MDL: Method detection limit or minimum reporting limit.

Quality Control: All associated Quality Control data is available on request.

LCL: Lower Control Limit.

UCL: Upper Control Limit.

QAQCID: This is a unique reference to the quality control data set used to generate the reported value. Contact our lab for this information, as it is traceable through our LIMS.

Field Data: Reports containing Field Parameters represent data that has been collected and provided by the client. Testmark is not responsible for the validity of this data which may be used in subsequent calculations.

Sample Condition Deviations: A noted sample condition deviation may affect the validity of the result. Results apply to the sample(s) as received.

Reproduction of Report: Report shall not be reproduced, except in full, without the approval of Testmark Laboratories Ltd.



CERTIFICATE OF ANALYSIS

RDSB - Churchill Public School

Work Order Number: 445514

QUALITY CONTROL DATA

THIS SECTION REPORTS QC RESULTS ASSOCIATED WITH THE TEST BATCH; THESE ARE NOT YOUR SAMPLE RESULTS. QAQC details include only values where sufficient sample data allowed measurement.

Metals

Method Blank: LRB-6 (Blank) (6)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	0.1	ug/L	0	<0.1	1	20211018.A13.1G

Positive Control: LFB-7 (N 100 µg/L) (7)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	N/A	%	80	98.6	120	20211018.A13.1G

Reference Sample: CRM-12 (EP-L-3) (12)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	1	ug/L	2.58	4.2	5.38	20211018.A13.1G

Sample Spike: LFMS-9 (N 100 µg/L) (9)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	N/A	% Rec	70	94.5	130	20211018.A13.1G

THIS INDEX SHOWS HOW YOUR SAMPLES ARE ASSOCIATED TO THE CONTROLS INCLUDED IN THE IDENTIFIED BATCHES.

Sample Description	Lab ID	Method	QAQCID	Prep QAQCID
Flushed - S - 4 Room 17 A	1694859	ICPMS Reg. Water (A13)	20211018.A13.1G	20211016.A52D
Flushed - S - 6 Room 4 Daycare	1694861	ICPMS Reg. Water (A13)	20211018.A13.1G	20211016.A52D
Standing - S - 4 Room 17 A	1694858	ICPMS Reg. Water (A13)	20211018.A13.1G	20211016.A52D
Standing - S - 6 Room 4 Daycare	1694860	ICPMS Reg. Water (A13)	20211018.A13.1G	20211016.A52D