



## CERTIFICATE OF ANALYSIS

Client: Lisa Polano  
Company: RDSB - Larchwood Public School  
Address: 408 Wembley Drive  
Sudbury, ON, P3E 1P2  
Phone: (705) 690-5929  
Email: polanol@rainbowschools.ca

Work Order Number: 463571  
PO #:   
Regulation: O.Reg. 243/07  
Project #:   
DWS #: 500046086  
Sampled By: illegible

Date Order Received: 5/24/2022  
Arrival Temperature: 15 °C

Analysis Started: 5/26/2022  
Analysis Completed: 5/26/2022

### WORK ORDER SUMMARY

ANALYSES WERE PERFORMED ON THE FOLLOWING SAMPLES. THE RESULTS RELATE ONLY TO THE ITEMS TESTED.

| Sample Description          | Lab ID  | Matrix | Type     | Comments | Date Collected | Time Collected |
|-----------------------------|---------|--------|----------|----------|----------------|----------------|
| Standing - Daycare T-4 Rm 8 | 1756438 | Water  | Plumbing |          | 5/24/2022      | 6:00 AM        |
| Flushed - Daycare T-4 Rm 8  | 1756439 | Water  | Plumbing |          | 5/24/2022      | 6:35 AM        |

### METHODS AND INSTRUMENTATION

THE FOLLOWING METHODS WERE USED FOR YOUR SAMPLE(S):

| Method                 | Lab    | Description                                | Reference                 |
|------------------------|--------|--|---------------------------|
| ICPMS Reg. Water (A13) | Garson | Determination of Metals in Water by ICP/MS | Modified from SW846-6020A |

This report has been approved by:

Mahesh Patel, B.Sc.  
Laboratory Director



## CERTIFICATE OF ANALYSIS

RDSB - Larchwood Public School

Work Order Number: 463571

### WORK ORDER RESULTS

| Sample Description | Standing - Daycare T - 4 Rm 8 |     | Flushed - Daycare T - 4 Rm 8 |     |       |                         |
|--------------------|-------------------------------|-----|------------------------------|-----|-------|-------------------------|
| Sample Date        | 5/24/2022 6:00 AM             |     | 5/24/2022 6:35 AM            |     |       |                         |
| Lab ID             | 1756438                       |     | 1756439                      |     |       |                         |
| Metals             | Result                        | MDL | Result                       | MDL | Units | Criteria: O.Reg. 243/07 |
| Lead               | 5.7                           | 0.1 | 2.3                          | 0.1 | ug/L  | 10                      |

### LEGEND

Dates: Dates are formatted as mm/dd/year throughout this report.

MDL: Method detection limit or minimum reporting limit.

Quality Control: All associated Quality Control data is available on request.

LCL: Lower Control Limit.

UCL: Upper Control Limit.

QAQCID: This is a unique reference to the quality control data set used to generate the reported value. Contact our lab for this information, as it is traceable through our LIMS.

Field Data: Reports containing Field Parameters represent data that has been collected and provided by the client. Testmark is not responsible for the validity of this data which may be used in subsequent calculations.

Sample Condition Deviations: A noted sample condition deviation may affect the validity of the result. Results apply to the sample(s) as received.

Reproduction of Report: Report shall not be reproduced, except in full, without the approval of Testmark Laboratories Ltd.

ICPMS Dustfall Insoluble: The ICPMS Dustfall Insoluble Portion method analyzes only the particulate matter from the Dustfall Sampler which is retained on the analysis filter during the Dustfall method.



**CERTIFICATE OF ANALYSIS**

RDSB - Larchwood Public School

Work Order Number: 463571

**QUALITY CONTROL DATA**

THIS SECTION REPORTS QC RESULTS ASSOCIATED WITH THE TEST BATCH; THESE ARE NOT YOUR SAMPLE RESULTS. QAQC details include only values where sufficient sample data allowed measurement.

**Metals**

**Method Blank: LRB-6 (Blank) (6)**

| Parameter | MDL | Units | LCL | Result | UCL | QAQCID          |
|-----------|-----|-------|-----|--------|-----|-----------------|
| Lead      | 0.1 | ug/L  | 0   | <0.1   | 1   | 20220526.A13.1F |

**Positive Control: LFB-7 (N 100 µg/L) (7)**

| Parameter | MDL | Units | LCL | Result | UCL | QAQCID          |
|-----------|-----|-------|-----|--------|-----|-----------------|
| Lead      | N/A | %     | 80  | 103    | 120 | 20220526.A13.1F |

**Reference Sample: CRM-12 (EP-L-3) (12)**

| Parameter | MDL | Units | LCL  | Result | UCL  | QAQCID          |
|-----------|-----|-------|------|--------|------|-----------------|
| Lead      | 1   | ug/L  | 2.58 | 4.26   | 5.38 | 20220526.A13.1F |

**Sample Spike: LFMS-9 (N 100 µg/L) (9)**

| Parameter | MDL | Units | LCL | Result | UCL | QAQCID          |
|-----------|-----|-------|-----|--------|-----|-----------------|
| Lead      | N/A | % Rec | 70  | 97.3   | 130 | 20220526.A13.1F |

THIS INDEX SHOWS HOW YOUR SAMPLES ARE ASSOCIATED TO THE CONTROLS INCLUDED IN THE IDENTIFIED BATCHES.

| Sample Description            | Lab ID  | Method                 | QAQCID          | Prep QAQCID    |
|-------------------------------|---------|------------------------|-----------------|----------------|
| Flushed - Daycare T - 4 Rm 8  | 1756439 | ICPMS Reg. Water (A13) | 20220526.A13.1F | 20220525.A52ZS |
| Standing - Daycare T - 4 Rm 8 | 1756438 | ICPMS Reg. Water (A13) | 20220526.A13.1F | 20220525.A52ZS |