



**TESTMARK Laboratories Ltd.**

Committed to Quality and Service

## CERTIFICATE OF ANALYSIS

Client:	Steve McCulloch	Work Order Number:	462835
Company:	RDSB - Charles C. McLean Public School	PO #:	
Address:	408 Wembley Drive Sudbury, ON, P3E 1P2	Regulation:	O.Reg. 243/07
Phone/Fax:	(705) 674-3171 / (705) 671-2442	Project #:	
Email:	mcculls@rainbowschools.ca	DWS #:	500039105
		Sampled By:	
Date Order Received:	5/16/2022	Analysis Started:	5/19/2022
Arrival Temperature:	3 °C	Analysis Completed:	5/19/2022

### WORK ORDER SUMMARY

ANALYSES WERE PERFORMED ON THE FOLLOWING SAMPLES. THE RESULTS RELATE ONLY TO THE ITEMS TESTED.

Sample Description	Lab ID	Matrix	Type	Comments	Date Collected	Time Collected
Standing-FB4	1753894	Water	Plumbing		5/14/2022	9:05 AM
Flushed-FB4	1753895	Water	Plumbing		5/14/2022	9:40 AM
Standing-FB6	1753896	Water	Plumbing		5/14/2022	9:15 AM
Flushed-FB6	1753897	Water	Plumbing		5/14/2022	9:50 AM

### METHODS AND INSTRUMENTATION

THE FOLLOWING METHODS WERE USED FOR YOUR SAMPLE(S):

Method	Lab	Description	Reference
ICPMS Reg. Water (A13)	Garson	Determination of Metals in Water by ICP/MS	Modified from SW846-6020A



**TESTMARK Laboratories Ltd.**

*Committed to Quality and Service*

## CERTIFICATE OF ANALYSIS

RDSB - Charles C. McLean Public School

Work Order Number: 462835

This report has been approved by:

Mahesh Patel, B.Sc.  
Laboratory Director



## CERTIFICATE OF ANALYSIS

RDSB - Charles C. McLean Public School

Work Order Number: 462835

### WORK ORDER RESULTS

Sample Description	Standing - FB4		Flushed - FB4		Standing - FB6		Flushed - FB6			
Sample Date	5/14/2022 9:05 AM		5/14/2022 9:40 AM		5/14/2022 9:15 AM		5/14/2022 9:50 AM			
Lab ID	1753894		1753895		1753896		1753897			
Metals	Result	MDL	Result	MDL	Result	MDL	Result	MDL	Units	Criteria: O.Reg. 243/07
Lead	0.5	0.1	0.2	0.1	0.5	0.1	0.2	0.1	ug/L	10

### LEGEND

Dates: Dates are formatted as mm/dd/year throughout this report.

MDL: Method detection limit or minimum reporting limit.

Quality Control: All associated Quality Control data is available on request.

LCL: Lower Control Limit.

UCL: Upper Control Limit.

QAQCID: This is a unique reference to the quality control data set used to generate the reported value. Contact our lab for this information, as it is traceable through our LIMS.

Field Data: Reports containing Field Parameters represent data that has been collected and provided by the client. Testmark is not responsible for the validity of this data which may be used in subsequent calculations.

Sample Condition Deviations: A noted sample condition deviation may affect the validity of the result. Results apply to the sample(s) as received.

Reproduction of Report: Report shall not be reproduced, except in full, without the approval of Testmark Laboratories Ltd.

ICPMS Dustfall Insoluble: The ICPMS Dustfall Insoluble Portion method analyzes only the particulate matter from the Dustfall Sampler which is retained on the analysis filter during the Dustfall method.



## CERTIFICATE OF ANALYSIS

RDSB - Charles C. McLean Public School

Work Order Number: 462835

### QUALITY CONTROL DATA

THIS SECTION REPORTS QC RESULTS ASSOCIATED WITH THE TEST BATCH; THESE ARE NOT YOUR SAMPLE RESULTS. QAQC details include only values where sufficient sample data allowed measurement.

#### Metals

##### Method Blank: LRB-6 (Blank) (6)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	0.1	ug/L	0	<0.1	1	20220519.A13.1D

##### Positive Control: LFB-7 (N 100 µg/L) (7)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	N/A	%	80	94.3	120	20220519.A13.1D

##### Reference Sample: CRM-12 (EP-L-3) (12)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	1	ug/L	2.58	3.92	5.38	20220519.A13.1D

##### Sample Spike: LFMS-9 (N 100 µg/L) (9)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	N/A	% Rec	70	88	130	20220519.A13.1D

THIS INDEX SHOWS HOW YOUR SAMPLES ARE ASSOCIATED TO THE CONTROLS INCLUDED IN THE IDENTIFIED BATCHES.

Sample Description	Lab ID	Method	QAQCID	Prep QAQCID
Flushed - FB4	1753895	ICPMS Reg. Water (A13)	20220519.A13.1D	20220518.A52F
Flushed - FB6	1753897	ICPMS Reg. Water (A13)	20220519.A13.1D	20220518.A52F
Standing - FB4	1753894	ICPMS Reg. Water (A13)	20220519.A13.1D	20220518.A52F
Standing - FB6	1753896	ICPMS Reg. Water (A13)	20220519.A13.1D	20220518.A52F