



**TESTMARK Laboratories Ltd.**

Committed to Quality and Service

## CERTIFICATE OF ANALYSIS

Client: Alain Venne  
Company: RDSB - Monetville Public School  
Address: 408 Wembley Drive  
Sudbury, ON, P3E 1P2  
Phone/Fax: (705) 919-3531 / (705) 671-2442  
Email: vennea@rainbowschools.ca

Work Order Number: 478381  
PO #:   
Regulation: O.Reg. 243/07  
Project #:   
DWS #: 500039092  
Sampled By: Alain Venne

Date Order Received: 9/29/2022  
Arrival Temperature: 7.1 °C

Analysis Started: 10/7/2022  
Analysis Completed: 10/7/2022

### WORK ORDER SUMMARY

ANALYSES WERE PERFORMED ON THE FOLLOWING SAMPLES. THE RESULTS RELATE ONLY TO THE ITEMS TESTED.

Sample Description	Lab ID	Matrix	Type	Comments	Date Collected	Time Collected
Standing-BF 1 by Room 305	1805716	Water	Plumbing		9/28/2022	6:30 AM
Flushed-BF 1 by Room 305	1805717	Water	Plumbing		9/28/2022	7:05 AM
Standing-BF02 by Room 403	1805718	Water	Plumbing		9/28/2022	6:35 AM
Flushed-BF02 by Room 403	1805719	Water	Plumbing		9/28/2022	7:10 AM

### METHODS AND INSTRUMENTATION

THE FOLLOWING METHODS WERE USED FOR YOUR SAMPLE(S):

Method	Lab	Description	Reference
ICPMS Reg. Water (A13)	Garson	Determination of Metals in Water by ICP/MS	Modified from SW846-6020A



**TESTMARK Laboratories Ltd.**

*Committed to Quality and Service*

## CERTIFICATE OF ANALYSIS

RDSB - Monctville Public School

Work Order Number: 478381

This report has been approved by:

Mahesh Patel, B.Sc.  
Laboratory Director



## CERTIFICATE OF ANALYSIS

RDSB - Monetville Public School

Work Order Number: 478381

### WORK ORDER RESULTS

Sample Description	Standing - BF 1 by Room 305		Flushed - BF 1 by Room 305		Standing - BF02 by Room 403		Flushed - BF02 by Room 403			
Sample Date	9/28/2022 6:30 AM		9/28/2022 7:05 AM		9/28/2022 6:35 AM		9/28/2022 7:10 AM			
Lab ID	1805716		1805717		1805718		1805719			
Metals	Result	MDL	Result	MDL	Result	MDL	Result	MDL	Units	Criteria: O.Reg. 243/07
Lead	<0.1	0.1	<0.1	0.1	<0.1	0.1	<0.1 <0.1	0.1	ug/L	10

### LEGEND

Dates: Dates are formatted as mm/dd/year throughout this report.

MDL: Method detection limit or minimum reporting limit.

[ ]: Results for laboratory replicates are shown in square brackets immediately below the associated sample result for ease of comparison.

Quality Control: All associated Quality Control data is available on request.

LCL: Lower Control Limit.

UCL: Upper Control Limit.

QAQCID: This is a unique reference to the quality control data set used to generate the reported value. Contact our lab for this information, as it is traceable through our LIMS.

Field Data: Reports containing Field Parameters represent data that has been collected and provided by the client. Testmark is not responsible for the validity of this data which may be used in subsequent calculations.

Sample Condition Deviations: A noted sample condition deviation may affect the validity of the result. Results apply to the sample(s) as received.

Reproduction of Report: Report shall not be reproduced, except in full, without the approval of Testmark Laboratories Ltd.

ICPMS Dustfall Insoluble: The ICPMS Dustfall Insoluble Portion method analyzes only the particulate matter from the Dustfall Sampler which is retained on the analysis filter during the Dustfall method.

Regulation Comparisons: Disclaimer: Please note that regulation criteria are provided for comparative purposes, however the onus on ensuring the validity of this comparison rests with the client.



## CERTIFICATE OF ANALYSIS

RDSB - Monctville Public School

Work Order Number: 478381

### QUALITY CONTROL DATA

THIS SECTION REPORTS QC RESULTS ASSOCIATED WITH THE TEST BATCH; THESE ARE NOT YOUR SAMPLE RESULTS.  
QAQC details include only values where sufficient sample data allowed measurement.

#### Metals

##### Method Blank: LRB-6 (Blank) (6)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	0.1	ug/L	0	<0.1	0.3	20221007.A13.1B

##### Positive Control: LFB-7 (N 100 µg/L) (7)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	N/A	%	85	99.2	115	20221007.A13.1B

##### Reference Sample: CRM-12 (EP-L-3) (12)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	1	ug/L	2.58	4.21	5.38	20221007.A13.1B

##### Sample Spike: LFMS-9 (N 100 µg/L) (9)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	N/A	% Rec	70	99.1	130	20221007.A13.1B

THIS INDEX SHOWS HOW YOUR SAMPLES ARE ASSOCIATED TO THE CONTROLS INCLUDED IN THE IDENTIFIED BATCHES.

Sample Description	Lab ID	Method	QAQCID	Prep QAQCID
Flushed - BF 1 by Room 305	1805717	ICPMS Reg. Water (A13)	20221007.A13.1B	20221006.A52C
Flushed - BF02 by Room 403	1805719	ICPMS Reg. Water (A13)	20221007.A13.1B	20221006.A52C
Flushed - BF02 by Room 403	1805719r	ICPMS Reg. Water (A13)	20221007.A13.1B	20221006.A52C
Standing - BF 1 by Room 305	1805716	ICPMS Reg. Water (A13)	20221007.A13.1B	20221006.A52C
Standing - BF02 by Room 403	1805718	ICPMS Reg. Water (A13)	20221007.A13.1B	20221006.A52C