



CERTIFICATE OF ANALYSIS

Client:	Steve McCulloch	Work Order Number:	462837
Company:	RDSB - S. Geiger Public School	PO #:	
Address:	408 Wembley Drive Sudbury, ON, P3E 1P2	Regulation:	O.Reg. 243/07
Phone/Fax:	(705) 674-3171 / (705) 671-2442	Project #:	
Email:	mcculls@rainbowschools.ca	DWS #:	500045644
		Sampled By:	
Date Order Received:	5/16/2022	Analysis Started:	5/19/2022
Arrival Temperature:	2.9 °C	Analysis Completed:	5/19/2022

WORK ORDER SUMMARY

ANALYSES WERE PERFORMED ON THE FOLLOWING SAMPLES. THE RESULTS RELATE ONLY TO THE ITEMS TESTED.

Sample Description	Lab ID	Matrix	Type	Comments	Date Collected	Time Collected
Standing-S22B	1753908	Water	Plumbing		5/14/2022	4:45 PM
Flushed-S22B	1753909	Water	Plumbing		5/14/2022	5:20 PM
Standing-FB3	1753910	Water	Plumbing		5/14/2022	4:50 PM
Flushed-FB3	1753911	Water	Plumbing		5/14/2022	5:25 PM
Standing-S12B	1753912	Water	Plumbing		5/14/2022	4:55 PM
Flushed-S12B	1753913	Water	Plumbing		5/14/2022	5:30 PM
Standing-S27	1753914	Water	Plumbing		5/14/2022	5:00 PM
Flushed-S27	1753915	Water	Plumbing		5/14/2022	5:35 PM

METHODS AND INSTRUMENTATION

THE FOLLOWING METHODS WERE USED FOR YOUR SAMPLE(S):

Method	Lab	Description	Reference
ICPMS Reg. Water (A13)	Garson	Determination of Metals in Water by ICP/MS	Modified from SW846-6020A



TESTMARK Laboratories Ltd.

Committed to Quality and Service

CERTIFICATE OF ANALYSIS

RDSB - S. Geiger Public School

Work Order Number: 462837

This report has been approved by:

Mahesh Patel, B.Sc.
Laboratory Director



CERTIFICATE OF ANALYSIS

RDSB - S. Geiger Public School

Work Order Number: 462837

WORK ORDER RESULTS

Sample Description	Standing - S22B		Flushed - S22B		Standing - FB3		Flushed - FB3			
Sample Date	5/14/2022 4:45 PM		5/14/2022 5:20 PM		5/14/2022 4:50 PM		5/14/2022 5:25 PM			
Lab ID	1753908		1753909		1753910		1753911			
Metals	Result	MDL	Result	MDL	Result	MDL	Result	MDL	Units	Criteria: O.Reg. 243/07
Lead	0.8	0.1	0.6	0.1	0.8	0.1	0.6	0.1	ug/L	10
Sample Description	Standing - S12B		Flushed - S12B		Standing - S27		Flushed - S27			
Sample Date	5/14/2022 4:55 PM		5/14/2022 5:30 PM		5/14/2022 5:00 PM		5/14/2022 5:35 PM			
Lab ID	1753912		1753913		1753914		1753915			
Metals	Result	MDL	Result	MDL	Result	MDL	Result	MDL	Units	Criteria: O.Reg. 243/07
Lead	0.8	0.1	0.6	0.1	0.8	0.1	0.6	0.1	ug/L	10

LEGEND

Dates: Dates are formatted as mm/dd/year throughout this report.

MDL: Method detection limit or minimum reporting limit.

Quality Control: All associated Quality Control data is available on request.

LCL: Lower Control Limit.

UCL: Upper Control Limit.

QAQCID: This is a unique reference to the quality control data set used to generate the reported value. Contact our lab for this information, as it is traceable through our LIMS.

Field Data: Reports containing Field Parameters represent data that has been collected and provided by the client. Testmark is not responsible for the validity of this data which may be used in subsequent calculations.

Sample Condition Deviations: A noted sample condition deviation may affect the validity of the result. Results apply to the sample(s) as received.

Reproduction of Report: Report shall not be reproduced, except in full, without the approval of Testmark Laboratories Ltd.

ICPMS Dustfall Insoluble: The ICPMS Dustfall Insoluble Portion method analyzes only the particulate matter from the Dustfall Sampler which is retained on the analysis filter during the Dustfall method.



CERTIFICATE OF ANALYSIS

RDSB - S. Geiger Public School

Work Order Number: 462837

QUALITY CONTROL DATA

THIS SECTION REPORTS QC RESULTS ASSOCIATED WITH THE TEST BATCH; THESE ARE NOT YOUR SAMPLE RESULTS.
QAQC details include only values where sufficient sample data allowed measurement.

Metals

Method Blank: LRB-6 (Blank) (6)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	0.1	ug/L	0	<0.1	1	20220519.A13.1E

Positive Control: LFB-7 (N 100 µg/L) (7)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	N/A	%	80	99.7	120	20220519.A13.1E

Reference Sample: CRM-12 (EP-L-3) (12)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	1	ug/L	2.58	4.08	5.38	20220519.A13.1E

Sample Replicate: % RPD (4)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	N/A	%	0	3.3	20	20220519.A13.1E

Sample Spike: LFMS-9 (N 100 µg/L) (9)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	N/A	% Rec	70	96.4	130	20220519.A13.1E

THIS INDEX SHOWS HOW YOUR SAMPLES ARE ASSOCIATED TO THE CONTROLS INCLUDED IN THE IDENTIFIED BATCHES.

Sample Description	Lab ID	Method	QAQCID	Prep QAQCID
Flushed - FB3	1753911	ICPMS Reg. Water (A13)	20220519.A13.1E	20220518.A52G
Flushed - S12B	1753913	ICPMS Reg. Water (A13)	20220519.A13.1E	20220518.A52G
Flushed - S22B	1753909	ICPMS Reg. Water (A13)	20220519.A13.1E	20220518.A52G
Flushed - S27	1753915	ICPMS Reg. Water (A13)	20220519.A13.1E	20220518.A52G
Standing - FB3	1753910	ICPMS Reg. Water (A13)	20220519.A13.1E	20220518.A52G
Standing - S12B	1753912	ICPMS Reg. Water (A13)	20220519.A13.1E	20220518.A52G
Standing - S22B	1753908	ICPMS Reg. Water (A13)	20220519.A13.1E	20220518.A52G
Standing - S27	1753914	ICPMS Reg. Water (A13)	20220519.A13.1E	20220518.A52G