



TESTMARK Laboratories Ltd.

Committed to Quality and Service

CERTIFICATE OF ANALYSIS

Client: Carol Koziar
Company: RDSB - Westmount Avenue Public School
Address: 408 Wembley Drive
Sudbury, ON, P3E 1P2
Phone/Fax: (705) 690-0323 / (705) 671-2442
Email: koziarc@rainbowschools.ca

Work Order Number: 477692
PO #:
Regulation: O.Reg. 243/07
Project #:
DWS #: 500040288
Sampled By: Carol Koziar

Date Order Received: 9/23/2022
Arrival Temperature: 3 °C

Analysis Started: 9/30/2022
Analysis Completed: 9/30/2022

WORK ORDER SUMMARY

ANALYSES WERE PERFORMED ON THE FOLLOWING SAMPLES. THE RESULTS RELATE ONLY TO THE ITEMS TESTED.

| Sample Description | Lab ID | Matrix | Type | Comments | Date Collected | Time Collected |
|----------------------------|---------|--------|----------|----------|----------------|----------------|
| Standing- BF 02 by storage | 1802988 | Water | Plumbing | | 9/22/2022 | 6:30 AM |
| Flushed- BF 02 by storage | 1802989 | Water | Plumbing | | 9/22/2022 | 7:05 AM |

METHODS AND INSTRUMENTATION

THE FOLLOWING METHODS WERE USED FOR YOUR SAMPLE(S):

| Method | Lab | Description | Reference |
|------------------------|--------|--------------------------------------------|---------------------------|
| ICPMS Reg. Water (A13) | Garson | Determination of Metals in Water by ICP/MS | Modified from SW846-6020A |

This report has been approved by:

Mahesh Patel, B.Sc.
Laboratory Director



CERTIFICATE OF ANALYSIS

RDSB - Westmount Avenue Public School

Work Order Number: 477692

WORK ORDER RESULTS

| Sample Description | Standing - BF 02 by storage | | Flushed - BF 02 by storage | | | |
|--------------------|-----------------------------|-----|----------------------------|-----|-------|-------------------------|
| Sample Date | 9/22/2022 6:30 AM | | 9/22/2022 7:05 AM | | | |
| Lab ID | 1802988 | | 1802989 | | | |
| Metals | Result | MDL | Result | MDL | Units | Criteria: O.Reg. 243/07 |
| Lead | <0.1 | 0.1 | <0.1 | 0.1 | ug/L | 10 |

LEGEND

Dates: Dates are formatted as mm/dd/year throughout this report.

MDL: Method detection limit or minimum reporting limit.

Quality Control: All associated Quality Control data is available on request.

LCL: Lower Control Limit.

UCL: Upper Control Limit.

QAQCID: This is a unique reference to the quality control data set used to generate the reported value. Contact our lab for this information, as it is traceable through our LIMS.

Field Data: Reports containing Field Parameters represent data that has been collected and provided by the client. Testmark is not responsible for the validity of this data which may be used in subsequent calculations.

Sample Condition Deviations: A noted sample condition deviation may affect the validity of the result. Results apply to the sample(s) as received.

Reproduction of Report: Report shall not be reproduced, except in full, without the approval of Testmark Laboratories Ltd.

ICPMS Dustfall Insoluble: The ICPMS Dustfall Insoluble Portion method analyzes only the particulate matter from the Dustfall Sampler which is retained on the analysis filter during the Dustfall method.

Regulation Comparisons: Disclaimer: Please note that regulation criteria are provided for comparative purposes, however the onus on ensuring the validity of this comparison rests with the client.



CERTIFICATE OF ANALYSIS

RDSB - Westmount Avenue Public School

Work Order Number: 477692

QUALITY CONTROL DATA

THIS SECTION REPORTS QC RESULTS ASSOCIATED WITH THE TEST BATCH; THESE ARE NOT YOUR SAMPLE RESULTS.
QAQC details include only values where sufficient sample data allowed measurement.

Metals

| Method Blank: LRB-6 (Blank) (6) | | | | | | | |
|------------------------------------------|-----|-------|------|--------|------|-----------------|--|
| Parameter | MDL | Units | LCL | Result | UCL | QAQCID | |
| Lead | 0.1 | ug/L | 0 | <0.1 | 0.3 | 20220930.A13.1D | |
| Positive Control: LFB-7 (N 100 µg/L) (7) | | | | | | | |
| Parameter | MDL | Units | LCL | Result | UCL | QAQCID | |
| Lead | N/A | % | 85 | 97.4 | 115 | 20220930.A13.1D | |
| Reference Sample: CRM-12 (EP-L-3) (12) | | | | | | | |
| Parameter | MDL | Units | LCL | Result | UCL | QAQCID | |
| Lead | 1 | ug/L | 2.58 | 3.94 | 5.38 | 20220930.A13.1D | |
| Sample Spike: LFMS-9 (N 100 µg/L) (9) | | | | | | | |
| Parameter | MDL | Units | LCL | Result | UCL | QAQCID | |
| Lead | N/A | % Rec | 70 | 96.5 | 130 | 20220930.A13.1D | |

THIS INDEX SHOWS HOW YOUR SAMPLES ARE ASSOCIATED TO THE CONTROLS INCLUDED IN THE IDENTIFIED BATCHES.

| Sample Description | Lab ID | Method | QAQCID | Prep QAQCID |
|-----------------------------|---------|------------------------|-----------------|---------------|
| Flushed - BF 02 by storage | 1802989 | ICPMS Reg. Water (A13) | 20220930.A13.1D | 20220929.A52M |
| Standing - BF 02 by storage | 1802988 | ICPMS Reg. Water (A13) | 20220930.A13.1D | 20220929.A52M |