



**TESTMARK Laboratories Ltd.**

Committed to Quality and Service

## CERTIFICATE OF ANALYSIS

Client:	Steve McCulloch	Work Order Number:	534230
Company:	RDSB - Walden Public School	PO #:	
Address:	408 Wembley Drive Sudbury, ON, P3E 1P2	Regulation:	O.Reg. 243/07
Phone/Fax:	(705) 674-3171 / (705) 671-2442	Project #:	
Email:	mcculls@rainbowschools.ca	DWS #:	500039118
		Sampled By:	Steve McCulloch
Date Order Received:	5/13/2024	Analysis Started:	5/14/2024
Arrival Temperature:	10.3 C	Analysis Completed:	5/15/2024

### WORK ORDER SUMMARY

ANALYSES WERE PERFORMED ON THE FOLLOWING SAMPLES. THE RESULTS RELATE ONLY TO THE ITEMS TESTED.

Sample Description	Lab ID	Matrix	Type	Comments	Date Collected	Time Collected
Standing -FU5	2004183	Water	Plumbing		5/11/2024	9:00 PM
Flushed -FU5	2004184	Water	Plumbing		5/11/2024	9:35 PM
Standing -ST111	2004185	Water	Plumbing		5/11/2024	9:05 PM
Flushed -ST111	2004186	Water	Plumbing		5/11/2024	9:40 PM
Standing -S107	2004187	Water	Plumbing		5/11/2024	9:10 PM
Flushed -S107	2004188	Water	Plumbing		5/11/2024	9:45 PM

### METHODS AND INSTRUMENTATION

THE FOLLOWING METHODS WERE USED FOR YOUR SAMPLE(S):

Method	Lab	Description	Reference
ICPMS Reg. Water (A13)	Garson	Determination of Metals in Water by ICP/MS	Modified from SW846-6020A



**CERTIFICATE OF ANALYSIS**

RDSB - Walden Public School

Work Order Number: 534230

This report has been approved by:

Brad Halvorson, B.Sc.  
Laboratory Director

**WORK ORDER RESULTS**

Sample Description	Standing - FU5		Flushed - FU5		Standing - ST111		Flushed - ST111			
Sample Date	5/11/2024 9:00 PM		5/11/2024 9:35 PM		5/11/2024 9:05 PM		5/11/2024 9:40 PM			
Lab ID	2004183		2004184		2004185		2004186			
Metals	Result	MDL	Result	MDL	Result	MDL	Result	MDL	Units	Criteria: O.Reg. 243/07
Lead	0.3	0.1	0.5	0.1	0.3	0.1	0.5	0.1	ug/L	10

Sample Description	Standing - S107		Flushed - S107			
Sample Date	5/11/2024 9:10 PM		5/11/2024 9:45 PM			
Lab ID	2004187		2004188			
Metals	Result	MDL	Result	MDL	Units	Criteria: O.Reg. 243/07
Lead	0.3	0.1	0.5	0.1	ug/L	10



**TESTMARK Laboratories Ltd.**

*Committed to Quality and Service*

## CERTIFICATE OF ANALYSIS

RDSB - Walden Public School

Work Order Number: 534230

### LEGEND

Dates: Dates are formatted as mm/dd/year throughout this report.

MDL: Method detection limit or minimum reporting limit.

Organic Soil Analysis: Data reported for organic analysis in soils samples are corrected for moisture content.

Quality Control: All associated Quality Control data is available on request.

LCL: Lower Control Limit.

UCL: Upper Control Limit.

QAQCID: This is a unique reference to the quality control data set used to generate the reported value. Contact our lab for this information, as it is traceable through our LIMS.

Field Data: Reports containing Field Parameters represent data that has been collected and provided by the client. Testmark is not responsible for the validity of this data which may be used in subsequent calculations.

Sample Condition Deviations: A noted sample condition deviation may affect the validity of the result. Results apply to the sample(s) as received.

Reproduction of Report: Report shall not be reproduced, except in full, without the approval of Testmark Laboratories Ltd.

ICPMS Dustfall Insoluble: The ICPMS Dustfall Insoluble Portion method analyzes only the particulate matter from the Dustfall Sampler which is retained on the analysis filter during the Dustfall method.

Regulation Comparisons: Disclaimer: Please note that regulation criteria are provided for comparative purposes, however the onus on ensuring the validity of this comparison rests with the client.



**CERTIFICATE OF ANALYSIS**

RDSB - Walden Public School

Work Order Number: 534230

**QUALITY CONTROL DATA**

THIS SECTION REPORTS QC RESULTS ASSOCIATED WITH THE TEST BATCH; THESE ARE NOT YOUR SAMPLE RESULTS. QAQC details include only values where sufficient sample data allowed measurement.

<b>Metals</b>							
<b>Method Blank: LRB-6 (Blank) (6)</b>							
Parameter	MDL	Units	LCL	Result	UCL	QAQCID	
Lead	0.1	ug/L	0	<0.1	0.3	20240515.A13.1C	
<b>Positive Control: LFB-7 (N 100 µg/L) (7)</b>							
Parameter	MDL	Units	LCL	Result	UCL	QAQCID	
Lead	N/A	%	85	98.1	115	20240515.A13.1C	
<b>Reference Sample: CRM-12 (EP-L-3) (12)</b>							
Parameter	MDL	Units	LCL	Result	UCL	QAQCID	
Lead	1	ug/L	2.58	4.14	5.38	20240515.A13.1C	
<b>Sample Spike: LFMS-9 (N 100 µg/L) (9)</b>							
Parameter	MDL	Units	LCL	Result	UCL	QAQCID	
Lead	N/A	% Rec	70	100	130	20240515.A13.1C	

THIS INDEX SHOWS HOW YOUR SAMPLES ARE ASSOCIATED TO THE CONTROLS INCLUDED IN THE IDENTIFIED BATCHES.

Sample Description	Lab ID	Method	QAQCID	Prep QAQCID
Flushed - FU5	2004184	ICPMS Reg. Water (A13)	20240515.A13.1C	20240514.A52ZZB
Flushed - S107	2004188	ICPMS Reg. Water (A13)	20240515.A13.1C	20240514.A52ZZB
Flushed - ST111	2004186	ICPMS Reg. Water (A13)	20240515.A13.1C	20240514.A52ZZB
Standing - FU5	2004183	ICPMS Reg. Water (A13)	20240515.A13.1C	20240514.A52ZZB
Standing - S107	2004187	ICPMS Reg. Water (A13)	20240515.A13.1C	20240514.A52ZZB
Standing - ST111	2004185	ICPMS Reg. Water (A13)	20240515.A13.1C	20240514.A52ZZB