

**TESTMARK Laboratories Ltd.***Committed to Quality and Service*

CERTIFICATE OF ANALYSIS

Client: Carol Koziar
Company: RDSB - Westmount Avenue Public School
Address: 408 Wembley Drive
Sudbury, ON, P3E 1P2
Phone/Fax: (705) 690-0323 / (705) 671-2442
Email: koziarc@rainbowschools.ca

Work Order Number: 551908
PO #:
Regulation: O.Reg. 243/07
Project #:
DWS #: 500040288
Sampled By: Carol Koziar

Date Order Received: 10/1/2024
Arrival Temperature: 6 C

Analysis Started: 10/7/2024
Analysis Completed: 10/8/2024

WORK ORDER SUMMARY

ANALYSES WERE PERFORMED ON THE FOLLOWING SAMPLES. THE RESULTS RELATE ONLY TO THE ITEMS TESTED.

Sample Description	Lab ID	Matrix	Type	Comments	Date Collected	Time Collected
Standing- BF1 by rm 7	2062027	Water	Plumbing		9/29/2024	6:30 AM
Flushed- BF1 by rm 7	2062028	Water	Plumbing		9/29/2024	7:05 AM
Standing- BF 2 by gym	2062029	Water	Plumbing		9/29/2024	6:35 AM
Flushed- BF 2 by gym	2062030	Water	Plumbing		9/29/2024	7:10 AM
Standing- S-1 kitchen	2062031	Water	Plumbing		9/29/2024	6:40 AM
Flushed- S-1 kitchen	2062032	Water	Plumbing		9/29/2024	7:15 AM

METHODS AND INSTRUMENTATION

THE FOLLOWING METHODS WERE USED FOR YOUR SAMPLE(S):

Method	Lab	Description	Reference
ICPMS Reg. Water (A13)	Garson	Determination of Metals in Water by ICP/MS	Modified from SW846-6020A



TESTMARK Laboratories Ltd.

Committed to Quality and Service

CERTIFICATE OF ANALYSIS

RDSB - Westmount Avenue Public School

Work Order Number: 551908

This report has been approved by:

Brad Halvorson, B.Sc.

Laboratory Director

WORK ORDER RESULTS

Sample Description	Standing - BF1 by rm 7		Flushed - BF1 by rm 7		Standing - BF 2 by gym		Flushed - BF 2 by gym			
Sample Date	9/29/2024 6:30 AM		9/29/2024 7:05 AM		9/29/2024 6:35 AM		9/29/2024 7:10 AM			
Lab ID	2062027		2062028		2062029		2062030			
Metals	Result	MDL	Result	MDL	Result	MDL	Result	MDL	Units	Criteria: O.Reg. 243/07
Lead	<0.1	0.1	<0.1	0.1	<0.1	0.1	<0.1	0.1	ug/L	10

Sample Description	Standing - S - 1 kitchen		Flushed - S - 1 kitchen			
Sample Date	9/29/2024 6:40 AM		9/29/2024 7:15 AM			
Lab ID	2062031		2062032			
Metals	Result	MDL	Result	MDL	Units	Criteria: O.Reg. 243/07
Lead	1.3	0.1	1.3 [1.3]	0.1	ug/L	10



TESTMARK Laboratories Ltd.

Committed to Quality and Service

CERTIFICATE OF ANALYSIS

RDSB - Westmount Avenue Public School

Work Order Number: 551908

LEGEND

Dates: Dates are formatted as mm/dd/year throughout this report.

MDL: Method detection limit or minimum reporting limit.

[]: Results for laboratory replicates are shown in square brackets immediately below the associated sample result for ease of comparison.

Organic Soil Analysis: Data reported for organic analysis in soils samples are corrected for moisture content.

Quality Control: All associated Quality Control data is available on request.

Field Data: Reports containing Field Parameters represent data that has been collected and provided by the client. Testmark is not responsible for the validity of this data which may be used in subsequent calculations.

Sample Condition Deviations: A noted sample condition deviation may affect the validity of the result. Results apply to the sample(s) as received.

Reproduction of Report: Report shall not be reproduced, except in full, without the approval of Testmark Laboratories Ltd.

ICPMS Dustfall Insoluble: The ICPMS Dustfall Insoluble Portion method analyzes only the particulate matter from the Dustfall Sampler which is retained on the analysis filter during the Dustfall method.

Regulation Comparisons: Disclaimer: Please note that regulation criteria are provided for comparative purposes, however the onus on ensuring the validity of this comparison rests with the client.