

**TESTMARK Laboratories Ltd.***Committed to Quality and Service*

## CERTIFICATE OF ANALYSIS

Client: Steve McCulloch  
Company: RDSB - Assiginack Public School  
Address: 408 Wembley Drive  
Sudbury, ON, P3E 1P2  
Phone: (705) 674-3171  
Email: mcculls@rainbowschools.ca

Work Order Number: 575129  
PO #:   
Regulation: O.Reg. 243/07  
Project #:   
DWS #: 500001132  
Sampled By: SM

Date Order Received: 5/5/2025  
Arrival Temperature: 5.8 C

Analysis Started: 5/6/2025  
Analysis Completed: 5/7/2025

## WORK ORDER SUMMARY

ANALYSES WERE PERFORMED ON THE FOLLOWING SAMPLES. THE RESULTS RELATE ONLY TO THE ITEMS TESTED.

Sample Description	Lab ID	Matrix	Type	Comments	Date Collected	Time Collected
Standing - F3	2135934	Water	Plumbing		5/4/2025	12:05 PM
Flushed - F3	2135935	Water	Plumbing		5/4/2025	12:40 PM
Standing - F6	2135936	Water	Plumbing		5/4/2025	12:10 PM
Flushed - F6	2135937	Water	Plumbing		5/4/2025	12:45 PM
Standing - S124B	2135938	Water	Plumbing		5/4/2025	12:15 PM
Flushed - S124B	2135939	Water	Plumbing		5/4/2025	12:50 PM
Standing - S103	2135940	Water	Plumbing		5/4/2025	12:20 PM
Flushed - S103	2135941	Water	Plumbing		5/4/2025	12:55 PM
Standing - S140	2135942	Water	Plumbing		5/4/2025	12:25 PM
Flushed - S140	2135943	Water	Plumbing		5/4/2025	1:00 PM

## METHODS AND INSTRUMENTATION

THE FOLLOWING METHODS WERE USED FOR YOUR SAMPLE(S):

Method	Lab	Description	Reference
ICPMS Reg. Water (A13.1)	Garson	Determination of Metals in Water by ICP/MS	Modified from SW846-6020A

**TESTMARK Laboratories Ltd.***Committed to Quality and Service*

## CERTIFICATE OF ANALYSIS

RDSB - Assiginack Public School

Work Order Number: 575129

This report has been approved by:

Aline de Chevigny

Production Coordinator CET

## WORK ORDER RESULTS

Sample Description	Standing - F3		Flushed - F3		Standing - F6		Flushed - F6			
Sample Date	5/4/2025 12:05 PM		5/4/2025 12:40 PM		5/4/2025 12:10 PM		5/4/2025 12:45 PM			
Lab ID	2135934		2135935		2135936		2135937			
Metals	Result	MDL	Result	MDL	Result	MDL	Result	MDL	Units	Criteria: O.Reg. 243/07
Lead	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	ug/L	10

Sample Description	Standing - S124B		Flushed - S124B		Standing - S103		Flushed - S103			
Sample Date	5/4/2025 12:15 PM		5/4/2025 12:50 PM		5/4/2025 12:20 PM		5/4/2025 12:55 PM			
Lab ID	2135938		2135939		2135940		2135941			
Metals	Result	MDL	Result	MDL	Result	MDL	Result	MDL	Units	Criteria: O.Reg. 243/07
Lead	0.9	0.1	0.8	0.1	0.9	0.1	0.8	0.1	ug/L	10

Sample Description	Standing - S140		Flushed - S140			
Sample Date	5/4/2025 12:25 PM		5/4/2025 1:00 PM			
Lab ID	2135942		2135943			
Metals	Result	MDL	Result	MDL	Units	Criteria: O.Reg. 243/07
Lead	1.0	0.1	0.8	0.1	ug/L	10



**TESTMARK Laboratories Ltd.**

*Committed to Quality and Service*

## CERTIFICATE OF ANALYSIS

RDSB - Assignack Public School

Work Order Number: 575129

### LEGEND

Dates: Dates are formatted as mm/dd/year throughout this report.

MDL: Method detection limit or minimum reporting limit.

Organic Soil Analysis: Data reported for organic analysis in soils samples are corrected for moisture content.

Quality Control: All associated Quality Control data is available on request.

Field Data: Reports containing Field Parameters represent data that has been collected and provided by the client. Testmark is not responsible for the validity of this data which may be used in subsequent calculations.

Sample Condition Deviations: A noted sample condition deviation may affect the validity of the result. Results apply to the sample(s) as received.

Reproduction of Report: Report shall not be reproduced, except in full, without the approval of Testmark Laboratories Ltd.

ICPMS Dustfall Insoluble: The ICPMS Dustfall Insoluble Portion method analyzes only the particulate matter from the Dustfall Sampler which is retained on the analysis filter during the Dustfall method.

Regulation Comparisons: Disclaimer: Please note that regulation criteria are provided for comparative purposes, however the onus on ensuring the validity of this comparison rests with the client.