

**TESTMARK Laboratories Ltd.***Committed to Quality and Service*

CERTIFICATE OF ANALYSIS

Client: Steve McCulloch
Company: RDSB - Charles C. McLean Public School
Address: 408 Wembley Drive
Sudbury, ON, P3E 1P2
Phone/Fax: (705) 674-3171 / (705) 671-2442
Email: mcculls@rainbowschools.ca

Work Order Number: 575158
PO #:
Regulation: O.Reg. 243/07
Project #:
DWS #: 500039105
Sampled By: illegible

Date Order Received: 5/5/2025
Arrival Temperature: 5.8 C

Analysis Started: 5/6/2025
Analysis Completed: 5/7/2025

WORK ORDER SUMMARY

ANALYSES WERE PERFORMED ON THE FOLLOWING SAMPLES. THE RESULTS RELATE ONLY TO THE ITEMS TESTED.

Sample Description	Lab ID	Matrix	Type	Comments	Date Collected	Time Collected
Standing-FB2	2136139	Water	Plumbing		5/4/2025	3:00 PM
Flushed-FB2	2136140	Water	Plumbing		5/4/2025	3:35 PM
Standing-FB4	2136141	Water	Plumbing		5/4/2025	3:05 PM
Flushed-FB4	2136142	Water	Plumbing		5/4/2025	3:40 PM
Standing-FB6	2136143	Water	Plumbing		5/4/2025	3:10 PM
Flushed-FB6	2136144	Water	Plumbing		5/4/2025	3:45 PM
Standing-S2B	2136145	Water	Plumbing		5/4/2025	3:15 PM
Flushed-S2B	2136146	Water	Plumbing		5/4/2025	3:50 PM

METHODS AND INSTRUMENTATION

THE FOLLOWING METHODS WERE USED FOR YOUR SAMPLE(S):

Method	Lab	Description	Reference
ICPMS Reg. Water (A13.1)	Garson	Determination of Metals in Water by ICP/MS	Modified from SW846-6020A



TESTMARK Laboratories Ltd.

Committed to Quality and Service

CERTIFICATE OF ANALYSIS

RDSB - Charles C. McLean Public School

Work Order Number: 575158

This report has been approved by:

Aline de Chevigny

Production Coordinator CET

WORK ORDER RESULTS

Sample Description	Standing - FB2		Flushed - FB2		Standing - FB4		Flushed - FB4			
Sample Date	5/4/2025 3:00 PM		5/4/2025 3:35 PM		5/4/2025 3:05 PM		5/4/2025 3:40 PM			
Lab ID	2136139		2136140		2136141		2136142			
Metals	Result	MDL	Result	MDL	Result	MDL	Result	MDL	Units	Criteria: O.Reg. 243/07
Lead	0.9	0.1	0.9	0.1	0.4	0.1	0.1	0.1	ug/L	10

Sample Description	Standing - FB6		Flushed - FB6		Standing - S2B		Flushed - S2B			
Sample Date	5/4/2025 3:10 PM		5/4/2025 3:45 PM		5/4/2025 3:15 PM		5/4/2025 3:50 PM			
Lab ID	2136143		2136144		2136145		2136146			
Metals	Result	MDL	Result	MDL	Result	MDL	Result	MDL	Units	Criteria: O.Reg. 243/07
Lead	0.8	0.1	0.8	0.1	0.2	0.1	0.1	0.1	ug/L	10



TESTMARK Laboratories Ltd.

Committed to Quality and Service

CERTIFICATE OF ANALYSIS

RDSB - Charles C. McLean Public School

Work Order Number: 575158

LEGEND

Dates: Dates are formatted as mm/dd/year throughout this report.

MDL: Method detection limit or minimum reporting limit.

Organic Soil Analysis: Data reported for organic analysis in soils samples are corrected for moisture content.

Quality Control: All associated Quality Control data is available on request.

Field Data: Reports containing Field Parameters represent data that has been collected and provided by the client. Testmark is not responsible for the validity of this data which may be used in subsequent calculations.

Sample Condition Deviations: A noted sample condition deviation may affect the validity of the result. Results apply to the sample(s) as received.

Reproduction of Report: Report shall not be reproduced, except in full, without the approval of Testmark Laboratories Ltd.

ICPMS Dustfall Insoluble: The ICPMS Dustfall Insoluble Portion method analyzes only the particulate matter from the Dustfall Sampler which is retained on the analysis filter during the Dustfall method.

Regulation Comparisons: Disclaimer: Please note that regulation criteria are provided for comparative purposes, however the onus on ensuring the validity of this comparison rests with the client.