

**TESTMARK Laboratories Ltd.***Committed to Quality and Service*

CERTIFICATE OF ANALYSIS

Client: Steve McCulloch
Company: RDSB - C.R. Judd Public School
Address: 408 Wembley Drive
Sudbury, ON, P3E 1P2
Phone: (705) 862-1565
Email: mcculls@rainbowschools.ca

Work Order Number: 627718
PO #:
Regulation: O.Reg. 243/07
Project #:
DWS #: 500040301
Sampled By: Steve McCulloch

Date Order Received: 6/24/2026
Arrival Temperature: 13.3 C

Analysis Started: 6/25/2026
Analysis Completed: 6/26/2026

WORK ORDER SUMMARY

ANALYSES WERE PERFORMED ON THE FOLLOWING SAMPLES. THE RESULTS RELATE ONLY TO THE ITEMS TESTED.

Sample Description	Lab ID	Matrix	Type	Comments	Date Collected	Time Collected
T1 - Daycare Standing	2300869	Water	Plumbing		6/24/2026	6:00 AM
T1 - Daycare Flushed	2300870	Water	Plumbing		6/24/2026	6:35 AM
BF-3 Standing	2300871	Water	Plumbing		6/24/2026	6:10 AM
BF-3 Flushed	2300872	Water	Plumbing		6/24/2026	6:45 AM

METHODS AND INSTRUMENTATION

THE FOLLOWING METHODS WERE USED FOR YOUR SAMPLE(S):

Method	Lab	Description	Reference
ICPMS Reg. Water (A13.1)	Garson	Determination of Metals in Water by ICP/MS	Modified from SW846-6020A



TESTMARK Laboratories Ltd.

Committed to Quality and Service

CERTIFICATE OF ANALYSIS

RDSB - C.R. Judd Public School

Work Order Number: 627718

This report has been approved by:

Aline de Chevigny

Production Coordinator CET

WORK ORDER RESULTS

Sample Description	T1 - Daycare Standing		T1 - Daycare Flushed		BF - 3 Standing		BF - 3 Flushed			
Sample Date	6/24/2026 6:00 AM		6/24/2026 6:35 AM		6/24/2026 6:10 AM		6/24/2026 6:45 AM			
Lab ID	2300869		2300870		2300871		2300872			
Metals	Result	MDL	Result	MDL	Result	MDL	Result	MDL	Units	Criteria: O.Reg. 243/07
Lead	<0.1	0.1	<0.1	0.1	<0.1	0.1	<0.1	0.1	ug/L	10

LEGEND

Dates: Dates are formatted as mm/dd/year throughout this report.

MDL: Method detection limit or minimum reporting limit.

Quality Control: All associated Quality Control data is available on request.

LCL: Lower Control Limit.

UCL: Upper Control Limit.

QAQCID: This is a unique reference to the quality control data set used to generate the reported value. Contact our lab for this information, as it is traceable through our LIMS.

Field Data: Reports containing Field Parameters represent data that has been collected and provided by the client. Testmark is not responsible for the validity of this data which may be used in subsequent calculations.

Sample Condition Deviations: A noted sample condition deviation may affect the validity of the result. Results apply to the sample(s) as received.

Reproduction of Report: Report shall not be reproduced, except in full, without the approval of Testmark Laboratories Ltd.

Regulation Comparisons: Disclaimer: Please note that regulation criteria are provided for comparative purposes, however the onus on ensuring the validity of this comparison rests with the client.

**TESTMARK Laboratories Ltd.***Committed to Quality and Service*

CERTIFICATE OF ANALYSIS

RDSB - C.R. Judd Public School

Work Order Number: 627718

QUALITY CONTROL DATA

THIS SECTION REPORTS QC RESULTS ASSOCIATED WITH THE TEST BATCH; THESE ARE NOT YOUR SAMPLE RESULTS.

QAQC details include only values where sufficient sample data allowed measurement.

Metals

Method Blank: LRB-6 (Blank) (6)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	0.1	ug/L	0	<0.1	0.3	20260626.A13.1B

Reference Sample: CRM-12 (EP-L-3) (12)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	1	ug/L	2.58	4.17	5.38	20260626.A13.1B

Sample Spike: LFMS-9 (N 100 µg/L) (9)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	N/A	% Rec	70	101	130	20260626.A13.1B

Positive Control: LFB-7 (N 100 µg/L) (7)

Parameter	MDL	Units	LCL	Result	UCL	QAQCID
Lead	N/A	%	85	104	115	20260626.A13.1B

THIS INDEX SHOWS HOW YOUR SAMPLES ARE ASSOCIATED TO THE CONTROLS INCLUDED IN THE IDENTIFIED BATCHES.

Sample Description	Lab ID	Method	QAQCID	Prep QAQCID
BF - 3 Flushed	2300872	ICPMS Reg. Water (A13.1)	20260626.A13.1B	20260625.A52ZX
BF - 3 Standing	2300871	ICPMS Reg. Water (A13.1)	20260626.A13.1B	20260625.A52ZX
T1 - Daycare Flushed	2300870	ICPMS Reg. Water (A13.1)	20260626.A13.1B	20260625.A52ZX
T1 - Daycare Standing	2300869	ICPMS Reg. Water (A13.1)	20260626.A13.1B	20260625.A52ZX